

Contents

| Rotary Pumps, Basic Considerations in their Applications | 1-6 |
|--|-------|
| Positive Displacement, Rotary Pump Characteristics | 7 |
| Pump Horsepower and Efficiency | 8 |
| Suction Pressure | 8 |
| Filtration | 9 |
| Viscosity Data, Formulas and Conversion | 10-14 |
| Viscosity of Common Liquids | 15-20 |
| Viscosity Blending Chart | 21 |
| Newtonian and Non-Newtonian Fluids | 22-23 |
| Typical Shear Rate Curves | 24 |
| Conversion Data | 25-26 |
| Equivalent Values of Pressure | 27 |
| Properties of the Lower Atmosphere | 28 |
| ANSI Standard Pipe Flanges and Threads | 29-30 |
| Properties of Welded & Seamless Steel Pipe | 31 |
| Pressure Loss in Standard Steel Pipe and Fittings | 32-45 |
| IMO® Positive Displacement Rotary Pumps | 46 |
| GTS™Geared Twin Screw Pumps | 46-47 |
| CIG* Crescent Internal Gear Pumps | |
| IMO® Three-Screw Rotary Pumps | |
| I-MAG® Magnetic Drive Couplings | 52 |
| IMO® Quick Selection Chart | 53 |

Acknowledgements: Some of the material for this handbook has been extracted from the following sources: Hydraulic Institute, Texaco Inc., American National Standards Institute and Engineering Handbook, third edition.

Information furnished herein is believed accurate but Imo Industries Inc. assumes no liability whatsoever for use.

Rotary Pumps

Basic Considerations In Their Applications

In the application of rotary pumps there are certain factors which must be considered in order to insure a successful installation. These are fundamentally the same regardless of the fluids to be handled or the pumping conditions. Although the primary purpose of this paper is to acquaint you with these factors and their relation to rotary pumps it might be well to first briefly consider the various basic type of pumps.

In general, pumps may be put into three classes: centrifugal, reciprocating and rotary.

The centrifugal pump develops its pressure as a result of centrifugal force and is mostly used where large volumes at relatively low pressures are required. Pumps of this type operate at comparatively high speed usually direct connected to their driver. They are not, however, self-priming except in the case of some very special designs and the delivered capacity will vary considerably with any change in discharge pressure. Centrifugal pumps are not particularly adapted to handling viscous fluids; although they are occasionally used for applications of this nature, the efficiency usually drops off quite rapidly if viscosities above 500 to 1000 SSU are encountered.

The reciprocating pump has positive pressure characteristics and is used principally to handle small volumes at relatively high pressures. Due to its reciprocating motion and the inertia effect of the parts, speeds are relatively low. This type of pump is self-priming and the delivered capacity is practically constant regardless of discharge pressure. It can handle with uniformly high volumetric efficiency practically all types of fluids.

The rotary pump combines the rotary motion of the centrifugal with the positive pressure characteristics of the reciprocating pump. Like the reciprocating pump it is a positive displacement device that delivers with each revolution a given quantity of fluid, is self-priming, and gives practically constant delivered capacity regardless of pressure. Speeds are much higher, however, than normally found in reciprocating pumps with the result that in probably the majority of cases direct connected motors can be used. Rotaries are available for pumping practically any fluid that will flow, and their greatest field is in the handling of viscous fluids. The rotary pump is known as the "work horse of industry" and is today, keeping full the pipelines of many processes, that otherwise would be unable to function.

A rotary pump is a positive displacement pump consisting of a fixed casing containing gears, cams, screws, plungers or similar elements actuated by rotation of the drive shaft.

Pumps in this classification commonly fall into six basic types, the gear, the vane, the screw, the cam and piston, the shuttle block, and the multiple piston, practically all of which can be broken down into further subdivisions.

The gear type which is perhaps the most common, consists of the external gear (fig. 1) including spur, helical and herringbone teeth, the lobular or impeller type, (fig. 2) and the internal gear, (fig. 3). Depending on the design and service, gear type pumps may be furnished either with or without timing gears. All have constant displacement characteristics.

The vane type pumps consist essentially of the sliding vane (fig. 4) and swinging vane, or bucket types, (fig. 5). Although the majority are designed for constant displacement, there are designs available in the sliding vane type, wherein the displacement is accomplished by incorporating a device which governs the amount of vane movement.

Screw pumps may have one, two or three rotors with threads of various contours, depending on the design. The majority of two rotor pumps requires timing gears whereas the other types do not. All are of the constant displace-




Fig. 1 External Gear Pump

Fig. 2 Three Lobe Pump

Fig. 3 Internal Gear Pump




Fig. 4 Sliding Vane Pump

Fig. 5 Swinging Vane Pump

Fig. 6 Single Screw Pump

ment type and are illustrated by Figures 6, 7 and 8.

The cam and piston type (fig. 9) is exactly what its name implies. It combines the rotary motion of a cam in combination with a piston. Usually two sets are utilized 180° apart so that a fairly steady flow results. This type of pump is particularly applicable on high vacuum service.

The shuttle block pump (fig. 10) is essentially a piston type pump. It contains a slotted rotor having a pin set eccentric to it in such a manner that it will cause the pistons to move in and out as the rotor is turned. By varying the position of the pin differences in stroke can be obtained and as a result, variable displacement.

Multiple piston pumps may be of the radial or axial type (fig. 11&12). In either, a series of pistons are actuated by a rotor mounted off center in the casing. Pumps of this type have very high volumetric efficiences and are used a great deal in the hydraulic field, they are particularly well suited where variable displacement is desired.

The pumping action of all rotary pumps is essentially the same. As the pumping elements are rotated they open on the inlet side creating a void. The fluid, forced by atmospheric pressure, flows in to fill this space. The continued turning of the rotors encloses the fluid between

the rotating parts themselves, or between these parts and the pump casing.

Since the pump is a positive displacement device it is apparent that with every revolution of the shaft a definite quantity of fluid passes through. If no clearance existed this quantity, called "theoretical capacity," would be dependent only on the physical dimensions of the pumping elements and the speed. Clearances, however, do exist with the result that whenever a pressure differential occurs, there will always be internal leakage from the outlet side to the inlet side. This leakage, commonly known as "slip" may be relatively large or small depending on the type of pump, the amount of clearance, the viscosity of the fluid handled, and the differential between outlet and inlet pressures. For any given set of conditions it is usually unaffected by speed. The delivered or net capacity, therefore, is the theoretical capacity less the slippage.

The theoretical capacity of any pump can readily be calculated providing all the essential dimensions are known. Slip can likewise be calculated but is usually based on empirical values developed as a result of tests. This data is a part of the "stock in trade" of every pump manufacturer and capacities can be accurately predicted for any given set of conditions.

The selection of a pump for a specific application is not difficult if all of the operating conditions are known. It is often quite difficult, however, to obtain accurate information as to these conditions. This is particularly true with reference to inlet conditions and viscosity, since it is a common feeling that in as much as the rotary pump is a positive displacement device these items are unimportant.

In any rotary pump application regardless of the design, suction lift, viscosity, and speed are inseparable. In order to insure quiet, efficient operation, it is necessary to completely fill with available concerning the fluid in question. For instance "Bunker C or No. 6 Fuel Oil" is known to have a wide latitude as to viscosity and usually must be handled over a considerable temperature range. The normal procedure in a case of this type is to assume an operating viscosity range of 20 to 700 SSF. The maximum viscosity, however, might very easily exceed the higher value if extra heavy oil is used or exceptionally low temperatures are encountered. If either should occur the result may be improper filling




Fig. 7 Two Screw Pump

Fig. 8 Three Screw Pump

Fig. 9 Cam and Piston Pump

the fluid, the compartments in the pumping elements as they open and this becomes more difficult as viscosity or suction lift, or both increase. BASICALLY IF YOU GET THE FLUID INTO A PUMP, OR RATHER THE PUMPING ELEMENTS AS THEY OPEN, YOU CAN GET IT OUT: THE PROBLEM IS GETTING IT IN.

Speed of operation, therefore, is dependent on viscosity and suction lift. If a true picture of these two items can be obtained, the problem of making a proper pump selection becomes infinitely simpler and it is probable that the selection will result in a more efficient unit.

It is not very often that a rotary pump is called upon to handle fluids having a constant viscosity. Normally, due to temperature variations, it is expected that a range of viscosity will be encountered and this can be guite wide. for instance it is not unusual that a pump is required to handle a viscosity range of 150 to 20,000 SSU; the higher viscosity usually being due to cold starting conditions. This is a perfectly satisfactory range in so far as a rotary pump is concerned, but if information can be obtained concerning such things as the amount of time the pump is required to operate at the higher viscosity, whether the motor can be overloaded temporarily, a multi-speed motor used, or the discharge pressure reduced during this period, a better selection can often be made.

Quite often no viscosity is given but only the type of fluid. In such cases assumptions can sometimes be made if sufficient information is of the pumping elements, noisy operation, vibration, and overloading of the motor.

Although it is the maximum viscosity and the expected suction lift that determines the size of the pump and sets the speed, it is the minimum viscosity that determines the capacity. Rotary pumps must always be selected to give the specified capacity when handling the expected minimum viscosity since this is the point at which maximum slip, hence minimum capacity occurs. If this rule is not followed the pump will not meet the requirements of the system unless a considerable margin has been allowed initially in specifying capacity, or there is over-capacity available in the pump. The latter is often the case, since practically all rotary pumps are made in certain stock sizes and it is standard practice to apply the next larger pump when a capacity is specified that falls between sizes.

It should also be noted that the minimum viscosity often sets the model of the pump selected since it is more or less standard policy on the part of most manufacturers to down rate their pumps, in so far as allowable pressure is concerned, when handling liquids having a viscosity of less than 100 SSU. This is done for two reasons. First, to avoid the poorer volumetric efficiency as a result of increased slip under these conditions. Second, due to the fact that a film of the liquid must be maintained between the closely fitted parts which is likely to break down if a combination of low viscosity and high pressure should occur. Al-

though viscosity is not necessarily a definite criterion of film strength, it is generally so used by pump manufacturers.

The viscosity of most liquids, as for example water and mineral oil, are unaffected by any agitation to which they may be subjected as long as the temperature remains constant; they are accordingly known as "true" or "Newtonian," fluids. There is, however, another class of liquids such as cellulose compounds, glues, greases, paints, starches, slurries, candy compounds, etc., which change in viscosity as agitation is varied at constant temperature. Although to be absolutely correct different terms should be used to differentiate between increase or decrease at viscosity with rate of agitation, it is common practice to use the term "Thixotropy" to cover both.

If a liquid is known to be thixotropic the expected viscosity under actual pumping conditions should be determined since it can vary quite widely from the viscosity under static conditions. One instance comes to mind concerning the handling of a cellulose product where the viscosity was given as 20,000 SSU which was its actual static, or apparent, viscosity. It later developed that under actual pumping conditions the viscosity was approximately 500 SSU. No serious harm was done, but a large low speed pump was installed where a smaller, less expensive, higher speed unit could have been used.

The grease manufacturing industry is very familiar with the thixotropic properties of its products, as evidenced by the numerous curves which had been published wherein "apparent viscosity" is plotted against "rate of shear." The occasion is rare, however, when one is able to obtain accurate information as to viscosity, when it is necessary to select a pump for handling this material.

approximation could be given it would be of great help. Grease penetration test results are sometimes given, but since there is no relation between these values and the conditions under which the material must be pumped they do not mean too much.

For applications of this type the information, if available, which would be of the greatest value to a pump engineer is data taken from a similar installation. Such information should consist of type, size, capacity, and speed of already installed pumps, suction pressure, and temperature at the pump inlet flange, total working suction head, and above all the pressure drop in a specified length of piping. From the latter an excellent approximation of viscosity under actual operating conditions can be obtained.

Suction lift occurs where the total suction head at the pump inlet is below atmospheric pressure. It is normally the result of a static lift and pipe friction. Although rotary pumps are capable of producing a high vacuum it is not this vacuum that forces the fluid to flow. As previously explained, it is atmospheric pressure that forces the fluid into the pump. Since atmospheric pressure at sea-level corresponds to 14.7 psia or 30" Hg. this is the maximum amount of pressure available for moving the fluid and suction lift cannot exceed these figures. Actually it must be somewhat less, since there are always pump inlet losses which must be taken into account. It is considered the best practice to keep suction lifts just as low as possible.

The majority of rotary pumps operate with suction lifts of approximately 5 to 15" Hg. Lifts corresponding to 24-25" Hg. are not uncommon and there are numerous installations operating continuously and satisfactorily where the absolute suction pressure is within one half inch of the barometer. In the latter cases, however, the pumps are usually taking the fluid from




Fig. 10 Shuttle Block Pump




Fig. 11 Radial Plunger Pump




Fig. 12 Axial Plunger Pump

It is understood that it is practically impossible in most instances to give the viscosity of grease in the terms most familiar to the pump manufacture, i.e., Saybolt Seconds Universal or Saybolt Seconds Furol, but if only a rough tanks under vacuum and no entrained or dissolved air or gases are present. Great care must be taken in selecting pumps for these applications since the inlet losses can very easily exceed the net suction head available for moving the fluid into the pumping elements.

There are known instances of successful installations where pumps were properly selected for the suction conditions. There are also, unfortunately, many other installations with equally high suction lifts which are not so satisfactory. This is due to the fact that proper consideration was not given, at the time the installations were made, to the actual suction conditions at the pump inlet. Frequently, suction conditions are given as "flooded" simply because the source feeding the pump is above the inlet flange. Absolutely no consideration is given to outlet losses from the tank or pipe friction and these can be exceptionally high when dealing with extremely viscous fluids.

An outstanding and almost unbelievable example in this respect is one concerning an inquiry relative to the handling of glue at 20,000 SSU. Although the inquiry stated that the suction would be flooded, a request was made that the customer submit additional information concerning the piping layout on the suction side. When the information arrived it was found by calculating friction losses that although the tanks were elevated above the pump, and the total length of the suction line was only approximately 20 feet, the small size of the line plus a veritable maze of fittings and valves resulted in a total friction loss of approximately 350 pounds. This obviously is an impossible pumping condition.

Where it is desired to pump extremely viscous fluids such as grease, chilled shortening, cellulose preparations and the like, care should be taken to use the largest possible size of suction piping, eliminate all unnecessary fittings and valves, and to place the pump just as closely as possible to the source of supply. In addition, it may be found necessary to supply the fluid to the pump under some pressure, which may be supplied by elevation, air pressure, or mechanical means such as a screw conveyor.

It was previously stated that viscosity and speed are closely tied together and it is impossible to consider the one without the other. Although rotative speed is the ultimate outcome, the basic speed which the manufacturer must consider is the velocity of the fluid going through the pump; this is a function of pump type and design. Certain types such as gear and vane pumps carry the fluid around the periphery of the pumping elements and as a result the velocity of the fluid through the pump can become quite high unless relatively low rotative speeds are used. On the other hand, in screw type pumps, the flow is axial and fluid speeds are relatively lower with the result that higher rotative speeds can be used. Based on handling light fluids, say 100 to 500 SSU, gear or vane type pumps rarely exceed a rotative speed of 1800 RPM except in the case of a very small unit or special designs for a particular use, such as for aircraft purposes. Screw pumps, however, where timing gears are not required commonly operate without difficulty at speeds up to 5000 RPM and there are instances where special designs are operating at speeds of approximately 24,000 RPM taking oil under lift from a sump tank located below the pump.

Although rotative speeds are relative and dependent on the pump type, they usually should be reduced when handling fluids of high viscosity. This is due not only to the difficulty of filling the pumping elements, but also to the mechanical losses which result from the shearing action of these parts on the fluid handled. The reduction of these losses is frequently of more importance than relatively high speeds, even though the latter might be possible due to positive inlet conditions.

No direct comparison can be made as to mechanical loss between the various types of pumps, most manufacturers have established their own data on a basis of tests made under closely controlled operating conditions and these are so-called "trade secrets." In general, the losses for a given size and type of pump vary with the viscosity and rotative speed and may or may not be affected by pressure, depending on the type of pump under consideration. These losses, however, must always be based on the maximum viscosity to be handled, since they will be highest at this point. If this is not done the resultant calculated horsepower will be too low and a motor selected on this basis will probably be overloaded.

The other factor that determines the horsepower required to drive the pump is the actual work done in converting the fluid from its pressure condition on the inlet side to its corresponding condition on the outlet side. Since this work is done on all of the fluid (this must be so because slip does not exist until a pressure differential occurs), the volume which must be considered is not the delivered capacity but the actual displacement volume, or theoretical capacity, of the pump. Any number of formulae can be devised for calculating this value, known as the "theoretical liquid horsepower," depending on the units in which capacity and head, or pressure, are expressed. It should be noted that the theoretical liquid horsepower is independent of viscosity and is concerned only with the physical dimensions of the pumping elements, the rotative speed, and the total pressure.

The brake horsepower required is the sum of the theoretical liquid horsepower and the mechanical loss.

Rotary pumps are available in a wide variety of pressure ranges. Although the great majority are sold for pressures less than 150 psi, which is within the capabilities of almost any type of pump, a good size field exists for a great number up to 500 psi and literally thousands of precision pumps are built for hydraulic service on machine tools, and the like, where pressures up to 3000 psi may be encountered.

Rotary pumps do not in themselves create pressure, they simply transfer a quantity of fluid from the inlet to the outlet side. The pressure developed on the outlet side is solely the result of resistance to flow in the discharge line. If, for example, a pump were to be set up and run without a discharge line, a gauge placed at the pump outlet flange would register zero no matter how fast or how long it was run.

Resistance usually consists of differences of elevation, fixed resistances such as orifices, and pipe friction. Nothing much can be done about the first two since these are the basic reasons for using a pump, something however, can be done about pipe friction. Literally millions of dollars are thrown away annually due to the use of piping that is too small for the job. To be sure, all pipe friction cannot be eliminated as long as fluids must be handled in this manner but every effort should be made to use the largest pipe that is economically feasible. Numerous tables are available from which friction losses in any combination of piping may be calculated, among the most recent of which are those published by the Hydraulic Institute.

Before any new installation is made the cost of larger size piping which will result in lower pump pressures, should be carefully balanced against the cost of a less expensive pump, smaller motor, and a saving in horsepower over the expected life of the system. The larger piping may cost a little more in the beginning but the ultimate savings in power will often many times offset the original cost. These facts are particularly true of the handling of extremely viscous fluids and although most engineers dealing with fluids of this type are conscious of what can be done, it is surprising the number of installations encountered where considerable savings could have been made if a little more study had been made initially.

The question is frequently asked "What is the efficiency of a rotary pump?" This is rather difficult to answer because of the many variables. Efficiency is dependent on practically all of the factors already discussed such as size of pump, rotative speed, viscosity, and pressure differential. It can be calculated for any specified set of conditions but will vary with any change in these conditions.

Sometimes an attempt is made to calculate the efficiency on the basis of guaranteed capacity and brake horsepower, this is satisfactory provided that both were figured on the same viscosity. Normally, however, where rotary pumps are used a viscosity range has been specified or assumed, the capacity guaranteed on the minimum viscosity and the brake horse-power on the maximum. If these guarantee figures are used in an attempt to calculate efficiency a false value will result.

Good efficiencies can be obtained if a pump is properly selected to meet one set of conditions only. For example, medium size pumps of about 50 to 100 GPM capacity operating against 100 psi discharge pressure, normally have efficiencies of about 70% to 80%. Higher pressure pumps of about the same capacity, selected for optimum conditions, will give as high as 85% or 87%.

There is one other point that we have not as yet touched and that is the handling of fluids containing abrasives. Due to the fact that rotary pumps depend upon close clearances for proper pumping action the handling of abrasive fluids can cause wear. Some progress has been made in the use of harder and more abrasive resistant materials for the pumping elements so that a fair job can be done in some instances. It cannot be said, however, that performance is comparable to that obtained when handling clean fluids. On the whole, rotary pumps should not be used for handling fluids containing abrasives unless frequent replacements are acceptable.

Over the last twenty-year period, great progress has been made in the design and application of rotary pumps and further progress is being made constantly. Pumps of this type are available for the handling of fluids ranging from aviation gasoline and water to semi-plastics such as cellulose products, chilled shortening and greases. Where required, extremely high vacuum, pressures, and speeds are possible and practical.

If complete information is given as to suction conditions, viscosity, air or gas entrainment, discharge pressure, etc. so that a proper pump selection can be made, and the proper attention is paid to installation features particularly on the suction side, there is absolutely no reason why a satisfactory installation will not result.

In this day and age of specialization, pump specialists are available and can help you with your problems. Practically all manufacturers have sales and application engineers available who are familiar with the capabilities and limitations of their own products and usually of their competitor's as well. To be sure, their prime object is to sell their equipment, but very few of them desire to misapply that equipment or run the chance of a "trouble" installation. All have a background of successful installations and can be of invaluable help in assisting you.

Positive Displacement, Rotary Pump Characteristics

Theoretical Capacity—Q₁—pump displacement at 0 PSI differential pressure, in GPM.

Differential Pressure—△P—Algebraic sum of discharge pressure (gage) and suction pressure (gage)

"Slip"—Q_s—Internal leakage (through working clearances) due to △P, in GPM.

Delivered (rated) capacity—Q_c—theoretical capacity minus "slip."

Brake Horsepower—BHP—pump input horsepower.

The curves shown below demonstrate in general how capacity and BHP of most positive displacement rotary pumps vary with speed (pressure constant) and with pressure (speed constant). The effect of viscosity is also demonstrated.


Looking at the curves, one can see that theoretical capacity is directly proportional to speed and is constant regardless of differential pressure. The difference between theoretical capacity and delivered capacity is the "slip" of the


pump for a given viscosity. Depending on design, slip can be affected by speed, pressure and viscosity.

Since HP =
$$\frac{\text{GPM} \times \triangle P}{\text{constant}}$$
 both horsepower


curves increase as speed (capacity) or differential pressure increases. It is most important to note the effect of viscosity on horsepower. The difference between actual horsepower and theoretical horsepower for given viscosity is the mechanical loss and slip. Mechanical loss is primarily the loss within the pump due to the resistance of the fluid to shear. Mechanical loss increases with increasing speed and viscosity, and may or may not be dependent on differential pressure.

One significant point demonstrated by these curves is that theoretical capacity is directly proportional to speed while delivered capacity is not, due to the effect of "slip." Thus, half capacity cannot be achieved simply by operating at half speed.





NORSEPOWER TO SHEED



DIFFERENTIAL PRESSURE

Pump Horsepower and Efficiency

The brake horsepower required to drive a rotary pump is the sum of the theoretical liquid horsepower and the internal power losses. The theoretical liquid horsepower is the actual work done in moving the fluid from its inlet-pressure condition to the outlet at discharge pressure. This work is done on all the fluid of theoretical capacity, not just delivered capacity, as slip does not exist until a pressure differential occurs. Rotary pump power ratings are expressed in terms of horsepower (550 ft-lb/sec) and theoretical liquid horsepower is calculated:

$$tLhp = \frac{Q_T \triangle P}{1714}$$

Note that theoretical liquid horsepower is independent of viscosity and is concerned only with the physical dimensions of the pumping elements, the rotative speed, and the differential pressure.

The internal power losses are made up of two types: mechanical and viscous. The mechanical

Suction Pressure

The identification of the pump suction requirement is significant in any pump application. Specifying a higher suction lift than actually exists results in selection of a pump at a lower speed than necessary. Not only does this mean a larger, more expensive pump but also a costlier driver. Should the suction lift requirement be higher than specified, the outcome could be a noisy installation due to pump cavitation.

There is a common misconception that pumps "pull" fluid into the inlet opening unassisted by any outside force. Actually, fluid flows into the pump due to a difference in pressure between pump inlet and the fluid source. A primary step in pump selection is the calculation of system Net Inlet Pressure, sometimes called Net Positive Inlet Pressure. This is the absolute pressure above fluid vapor pressure at pump inlet and is determined as follows:

- Atmospheric pressure (at jobsite altitude— PSIA)
- Plus static head (minimum level of fluid above pump inlet—PSI)

or
Minus static lift (maximum level of fluid below pump inlet—PSI)

losses include all power necessary to overcome the mechanical friction drag of all the moving parts within the pump, including bearings, gears, mechanical seals, etc. The viscous losses include all the power lost from the fluid viscousdrag effects against all the parts within the pump as well as from the shearing action of the fluid itself. It is probable that the mechanical loss is the major component when operating at low viscosities and high speeds while the viscous loss is the larger at high viscosity and slow speed conditions.

 $\label{eq:Volumetric Efficiency} \begin{array}{l} \text{Volumetric Efficiency, } E_{\nu} = \frac{Q_{\text{G}}}{Q_{\text{T}}} \\ \\ \text{Overall Pump Efficiency, } E_{\text{cp}} = \frac{\text{OHP}}{\text{BHP}} \\ \\ \text{where OHP (oil horsepower)} = \frac{Q_{\text{G}} \ \triangle \ P}{1714} \\ \\ \text{Mechanical Efficiency, } E_{\text{T}} = \frac{E_{\text{cp}}}{E} \end{array}$


Q_c = delivery capacity, GPM Q_τ = theoretical capacity, GPM △P = differential pressure, PSI

- Minus inlet line friction losses including entrance loss from reservoir to pipe, pressure drops through valves, fittings, strainers, etc. (at maximum viscosity—PSI)
- Minus fluid vapor pressure (usually at maximum pumping temperature—PSIA)
- Equals system Net Inlet Pressure in PSIA,
 Note that when Net Inlet Pressure is expressed in feet of liquid, it is called Net Positive Suction Pressure.

System Net Inlet Pressure available must always equal or exceed pump Net Inlet Pressure required.

Suction conditions of rotary pumps are normally rated as suction lift capability in inches of mercury vacuum (with air-free oil of negligible vapor pressure at sea level). This can be expressed as Net Inlet Pressure required by subtracting suction lift capability from 30" Hg and converting the remainder to PSIA. Pump Net Inlet Pressure required must always be less than or equal to system Net Inlet Pressure available.

Suction condition is the most frequently overlooked parameter in pump selection. Time spent determining it accurately can optimize pump selection and result in a quiet installation.



Filtration


As mentioned, positive displacement rotary pumps are not ideally suited to handling abrasives. Relatively close clearances and actual part contact allow dirt, foreign material, etc. to cause scoring, galling, and in extreme cases jamming or seizure. Fine abrasives will cause wear which ultimately reduces pump capacity by increasing slip due to increased clearances.

Firm recommendations for fluid filters are very difficult to make. As a minimum, rotary pumps should have suction strainers to exclude such material as dirt, weld bead, slag, scale, chips, rags, nuts, bolts, etc. Since a suction strainer contributes to suction line loss, the degree of filtration must often be determined by acceptable frequency of cleaning, allowable

pressure drop, and cost. When pumping viscous fluids (over 5000 SSU), probably the finest suction filtration practical is 1/16". On light fluids such as distillate fuels, hydraulic oil, and light lube oils, suction strainers of 100 or even 200 mesh are feasible and highly desirable. On recirculating systems, pressure and return line filters of 25 or 10 microns are excellent and quite realistic. In hydraulic servo systems, 2 micron pressure filters are not uncommon.

Strainers and filters require periodic cleaning and, therefore, must be sized and instrumented accordingly. Since clogging of a suction strainer can cavitate a pump, it is particularly important to provide automatic protection by pressure switch or a similar device.

Particle Size Comparison and Conversion Chart



| MESH | INCHES | MICRONS | MESH | INCHES | MICRONS | MESH | INCHES | MICRONS |
|------|--------|---------|------|--------|---------|------|--------|---------|
| 3250 | 0.0002 | 6 | 130 | 0.0043 | 110 | 24 | 0.028 | 718 |
| 1600 | 0.0005 | 14 | 120 | 0.0046 | 118 | 20 | 0.034 | 872 |
| 750 | 0.0010 | 25 | 110 | 0.0051 | 131 | 18 | 0.039 | 1000 |
| 325 | 0.0016 | 40 | 100 | 0.0055 | 149 | 16 | 0.045 | 1154 |
| 250 | 0.0024 | 62 | 90 | 0.0061 | 156 | 14 | 0.051 | 1308 |
| 200 | 0.0029 | 74 | 80 | 0.0070 | 179 | 12 | 0.060 | 1538 |
| 180 | 0.0033 | 85 | 70 | 0.0078 | 200 | . 10 | 0.075 | 1923 |
| 170 | 0.0035 | 90 | 60 | 0.0092 | 238 | 8 | 0.097 | 2488 |
| 160 | 0.0038 | 97 | 50 | 0.0117 | 300 | 6 | 0.132 | 3385 |
| 150 | 0.0041 | 100 | 40 | 0.015 | 385 | 5 | 0.159 | 4077 |
| 140 | 0.0042 | 108 | 30 | 0.020 | 513 | 4 | 0.203 | 5205 |

Viscosity

Viscosity is that property of any fluid (liquid or gas) which tends to resist a shearing force. It is important to fluid flow because nearly all fluid motion is accompanied by shearing force.

The two basic viscosity parameters are the DYNAMIC (or ABSOLUTE) VISCOSITY, μ , having the dimension, $force \times time/(length)^2$, and the KINEMATIC VISCOSITY, v, having the dimension, $(length)^2/time$. The parameters are related through the mass density of the fluid, ρ , such that, $v = \mu/\rho = \mu g/\gamma$, where γ is the specific weight and g is the acceleration of gravity.

The unit of dynamic viscosity in English measure is the pound-second per square foot which is numerically identical with the slug per foot-second. The unit of dynamic viscosity in Metric measure is the dyne-second per square centimeter, called the POISE, which is numerically identical with the gram per centimeter-second. Numerical values generally are expressed in CENTIPOISES, a unit which is one hundredth of a Poise. A unit called the REYN, equal to one pound-second per square inch, is used in lubrication problems.

The unit of kinematic viscosity in English measure is the square foot per second. The unit of kinematic viscosity in Metric measure is the square centimeter per second, called the STOKE. Numerical values generally are expressed in CENTISTOKES, a unit which is one hundredth of a Stoke.

Widespread use of the Saybolt viscosimeter has led to the use of the time of efflux in seconds, for 60 cc. of liquid, as an arbritrary unit of kinematic viscosity. The term SSU (Seconds Saybolt Universal) refers to the smaller, and the term SSF (Seconds Saybolt Furol) refers to the larger of two orifices with which the instrument may be equipped. Other empirical measures of kinematic viscosity may be converted to basic units by the charts that follow.

The dynamic viscosity of any fluid is a function of temperature and pressure. The dynamic viscosity of most liquids increases with increase of pressure but, fortunately, the changes may be neglected for the ranges of pressure usually encountered in engineering problems. The dynamic viscosity of gases is virtually independent of pressure except at extremely high or low pressures. Pressure is very important in

determining the kinematic viscosity of a gas due to its influence on the mass density. Viscosities of air and water at 68°F, and atmospheric pressure are as follows:

| | Dynamic Viscosity µ | | Kinematic Viscos | | |
|--------------|--------------------------|--------------------------------|--------------------|-------------------------------|-----|
| Fluid | Poises | lb-sec/sq ft | Stokes | Sq ft/sec | SS |
| Air Water | 180.8 x 10-6 0.010087 | 0.3369 x 10-6 21.067 x 10-6 | 0.1501 0.010105 | 161.6 x 10-1 10.877 x 10-1 | 30. |

Viscosity Conversion Factors and Formulas

| Multiply | by | to obtain |
|-----------------------|--|------------------|
| Poises | 100 | centipoises |
| pound-seconds/sq. ft. | 47,880.1 | centipoises |
| Reyns | 6.89473 x 10-6 | centipoises |
| centipoises | 2.08855 x 10-5 | pound-seconds/sq |
| centipoises | 1.45038 x 10-7 | Reyns |
| Stokes | 100 | centistokes |
| sq. ft./second | 92,903.4 | centistokes |
| centistokes | 1.07639 x 10-5 | sq. ft./second |
| sq. ft./second | 1488.16 x y in pounds cu. ft. 6.71970 x 10-4 | centipoises |
| centipoises | γ in pounds/cu. ft. | sq. ft./second |
| | | |

Saybolt Viscosimeter Conversion Formulas

 μ , in centistokes - 0.226 x SSU - 195/SSU for SSU \leqslant 100 μ , in centistokes - 0.220 x SSU - 130/SSU for SSU > 100 μ , in centistokes - 2.24 x SSF - 184/SSF for 25 \leqslant SSF \leqslant μ , in centistokes - 2.16 x SSF - 60/SSF for SSF > 40

Viscosity Conversion Table

The following table will give a comparison of various viscosity ratings so that if the viscosity is given in terms other than Saybolt Universal, it can be translated quickly by following horizontally to the Saybolt Universal column.


| W. C. C. | | | | | | | | | |
|---------------------------------------|------------------------------|------------------------------|----------------------------------|---------------------------------|----------------------------------|---------------------------------|------------------------------------|-------------------------|------------|
| Seconds Saybolt Universal | 32 40 50 50 | 98288 | 100 200 250 250 | 900 900 900 900 900 | 000 000 000 000 000 | 2500 2500 3000 | 5000 6000 7000 7000 | 0000 0000 0000 | 15000 |
| Pratt and Lambert | | | F0808-8 | . ~ ∞ ೲ | 9.5 10.8 11.9 12.4 | 16.8 22 27.6 33.7 | 45 55.8 65.5 77 | 89 102 113 | 172 |
| Seconds Stormer 100 gm | 2.6 | 3.6 6.4 6.4 6.4 | 7.3 11.3 15.2 | 33 39 46 | 2327 | 116 154 193 232 | 308 385 462 540 | 618 695 770 | 1160 |
| Seconds Demmler Cup #10 | 3 6353 | a en . | 1.0 | 2.0 2.7 3.5 4.1 | 6.5 6.9 6.9 | 10.3 13.7 17.2 20.6 | 27.5 34.4 41.3 | 55 69 69 | 103 |
| Seconds Demmder Cup #1 | 1.3 | 3.2 4.1 5.7 | 6.5 13.5 16.9 | 20.4 27.4 34.5 41 | 48 55 62 69 | 103 137 172 206 | 275 344 413 481 | 550 620 690 | 1030 1 |
| Seconds Sahn Cup #5 Cup | 7 274 | a 101 i | | | 5 | 18 24 29 33 | 43 65 75 | 98 . | |
| Seconds S Zahn Cup #4 C | | | 10.3 | Server to | 118 | 28 34 41 48 | 27. | | - N |
| Seconds Zahn Cup #3 | a ray | | **** | | 22.5 24.5 27 29 | 40 51 63 75 | 10.00 | 88 8005 | |
| Seconds Zahn Cup #2 | 3 0252 | 20.000 | 20 23 26 26 | 29 37 46 55 | 63 72 80 88 | E + E + | 3 1 1 1 | 7 10 1 | |
| Seconds Zahn Cup #1 | | 1 1 0 0 | 38 47 54 62 | 90 | | C1 67 | 100 F. 10 F | 20.00 | *** |
| Gardner Gardner Holt Bubble | 4 4 4 4 | | 44 | 8004 | 0 · I - | ≅a⊦⊃ | >3× · | > ' N | Z2 Z3 |
| Approx. Seconds Mac Michael | 0.00 | 5 C F S | 125 145 165 198 | 225 270 320 370 | 420 470 515 570 | 805 1070 1325 1690 | 2110 2635 3145 3670 | 4170 4700 5220 | 7720 |
| Seconds Ford Cup #4 | 1 () | | A 1 0 0 | 28 34 40 | 45 57 62 | 90 118 147 172 | 230 290 350 410 | 465 520 575 | 1150 |
| Ford Ford Cup #3 | | | | 30 50 58 | 67 74 82 92 | 132 172 218 258 | 337 425 520 600 | 680 780 850 | 1280 |
| Seconds Parlin Cup #20 | 8 884 | n nen | 0.11976 | 3.2 | 3.9 4.1 4.5 | 6.3 7.5 9 | 14 22 25 25 | 323 | 53 |
| Seconds Parlin Cup #15 | | + + + + | | 6.0 7.2 7.8 8.5 | 9.0 10.7 11.5 | 15.2 19.5 24 28.5 | 37 57 67 | 76 86 96 | 147 |
| Seconds Parlin Cup #10 | | 1111 | 1.41 | 15 21 25 30 | 35 44 43 | 65 129 129 | 172 215 258 300 | 344 387 430 | 650 860 |
| Seconds Parlin Cup #7 | | | 40 | 52.5 66 79 92 | 106 120 135 149 | 56501930 | mus test | of test | 1/2 |
| Degrees Barbey | 2420 1440 838 | 618 483 404 348 | 307 195 144 114 | 95 70.8 56.4 47.0 | 40.3 35.2 31.3 28.2 | 18.7 14.1 11.3 | 7.05 5.64 4.70 4.03 | 3.52 3.13 2.82 | 1.40 |
| Degrees Engler | 1.162 | 1.88 2.17 2.45 2.73 | 3.02 4.48 5.92 7.35 | 8.79 11.70 14.60 17.50 | 20.45 23.35 26.30 29.20 | 43.80 58.40 73.0 87.60 | 117.0 146 175 204.5 | 233.5 263 292 | 438 584 |
| Seconds Redwood 2 (Admiralty) | 5.10 | 6.77 7.60 8.44 9.30 | 10.12 14.48 18.90 23.45 | | | 138.2 184.2 230 276 | 368 461 553 1 645 2 | 737 2 829 2 921 2 | 410 |
| - | 30.8 32.1 44.3 | 52.3 60.9 69.2 77.6 | 85.6 128 170 212 | 254 338 423 508 | | 1270 1690 2120 2540 | 3380 4230 5080 5920 | 6770 7620 8460 | 13700 |
| Saybolt Fural ssf | | 12.95 13.70 14.44 | 15.24 19.30 23.5 28.0 | 32.5 41.9 51.6 61.4 | 81.0 91.0 100.7 | 150 200 250 300 | 400 500 700 700 | 800 1000 | 1500 |
| Kinematic Viscosity Centistokes | 1.82 2.71 4.25 7.68 | 10.3 13.1 18.1 | 20.5 31.9 43.0 53.8 | 64.6 86.2 108 130 | 151 173 194 216 | 324 432 539 648 | 862 1079 1295 1510 | | 3240 |
| | 222 | 9828 | 100 200 250 | 80000 | 00000 | 2500 2500 3000 | 4000 5000 7000 7000 | | 15000 |

^{*}Kinematic Viscosity (in centistokes) - Absolute viscosity (in centipolises)


Above 300 SSU, use the following approximate conversion SSU = Centistokes x 4.635 Above the range of this table and within the range of the viscosimeter, multiply their rating by the following factors to convert to SSU.

| Viscosimeter | Factor | Viscosimeter | Factor | Viscosimeter | Factor |
|-------------------|--------|----------------|--------|--------------|---------------|
| Say bolt Furoi | 10. | Parlin cup #15 | 98.2 | Mac Michael | 1.92 (approx. |
| Redwood Standard | 1.095 | Parlin cup #20 | 187.0 | Demmler #1 | 14.6 |
| Redwood Admiralty | 10.87 | Ford cup # 4 | 17.4 | Demmler #10 | 146. |
| Engler Degrees | 34.5 | | | Stormer | 13. (approx. |


Effect of Temperature on Fuel Oil Viscosity



Effect of Temperature on Turbine Oil Viscosity



Effect of Temperature on SAE Crankcase Oil Viscosity



| Liquid | *6- C+ C0°F | VISCOSITY | | |
|--|---|------------------------------------|---------------------------------|----------------------|
| Liquia | *Sp Gr at 60°F | SSU | Centistokes | At F |
| ASPHALTS: Unblended or Virgin Asphalts | 1.1 to 1.5 | 2,500 to 12,000 600 to 3,600 | 539 to 2,810 130 to 776 | 250 300 |
| Blended Asphalt RS-1, MS-1 or SS-1 emulsified primer or binder | 1.0 approx. | 155 to 1,000 90 to 350 | 33 to 216 18.1 to 75.5 | 77 100 |
| RC-0, MC-0 or SC-0 cutbacks or binders | 1.0 approx. | 737 to 1,500 280 to 500 | 159 to 324 60.5 to 108 | 77 100 |
| RC-1, MC-1 or SC-1 cutbacks or binders | 1.0 approx. | 2,400 to 5,000 737 to 1,500 | 518 to 1,079 159 to 324 | 100 122 |
| RC-2, MC-2 or SC-2 cutbacks or binders | 1.0 approx. | 2,400 to 5,000 1,000 to 2,000 | 518 to 1,079 216 to 432 | 122 140 |
| RC-3, MC-3 or SC-3 cutbacks or binders | 1.0 approx. | 6,000 to 13,000 2,500 to 5,000 | 1,295 to 2,810 539 to 1,079 | 122 140 |
| RC-4, MC-4 or SC-4 cutbacks or binders | 1.0 approx. | 8,000 to 20,000 1,250 to 2,500 | 1,726 to 4,320 270 to 539 | 140 180 |
| RC-5, MC-5 or SC-5 cutbacks or binders | 1.0 approx. | 28,000 to 85,000 3,000 to 6,000 | 6,040 to 18,300 648 to 1,295 | 140 180 |
| CHEMICALS: Glycerine (100%) | 1.26 @ 68°F, | 2,950 813 | 648 176 | 68. 100 |
| Glycol: Propylene Triethylene Diethylene Ethylene | 1.038 @ 68° F. 1.125 @ 68° F. 1.12 @ 68° F. 1.125 @ 68° F. | 240.6 185.7 149.7 88.4 | 52 40 32 17.8 | 70 70 70 70 |
| FISH AND ANIMAL OILS: Bone Oil | .918 | 220 65 | 47.5 11.6 | 130 212 |
| Cod Oil | .928 | 150 95 | 32.1 19.4 | 100 |
| Lard | .96 | 287 160 | 62.1 34.3 | 100 130 |
| Lard Oil | .912 to .925 | 190 to 220 112 to 128 | 41 to 47.5 23.4 to 27.1 | 100 |
| Menhadden Oil | .933 | 140 90 | 29.8 18.2 | 100 |
| Neatsfoot Oil | .917 | 230 130 | 49.7 27.5 | 100 |
| Sperm Oil | .883 | 110 78 | 23.0 15.2 | 100 |
| Whale Oil | .925 | 163 to 184 97 to 112 | 35 to 39.6 19.9 to 23.4 | 100 130 |

^{*}Unless otherwise noted.

| | *0- 0 cole | VISCO | SITY | 4.0- |
|--|-----------------|------------------------------|-----------------------------------|-------------------|
| Liquid | *Sp Gr at 60°F, | SSU | Centistokes | - At°F |
| MINERAL OILS: Automobile Crankcase Oils (Average Midcontinent Paraffin Base): SAE 10 | **.880 to .935 | 165 to 240 90 to 120 | 35.4 to 51.9 18.2 to 25.3 | 100 |
| SAE 20 | **.880 to .935 | 240 to 400 120 to 185 | 51.9 to 86.6 25.3 to 39.9 | 100 |
| SAE 30 | **.880 to .935 | 400 to 580 185 to 255 | 86.6 to 125.5 39.9 to 55.1 | 100 |
| SAE 40 | **.880 to .935 | 580 to 950 255 to 80 | 125.5 to 205.6 55.1 to 15.6 | 100 130 210 |
| SAE 50 | **.880 to .935 | 950 to 1,600 80 to 105 | 205.6 to 352 15.6 to 21.6 | 100 |
| SAE 60 | **.880 to .935 | 1,600 to 2,300 105 to 125 | 352 to 507 21.6 to 26.2 | 100 210 |
| SAE 70 | **.880 to .935 | 2,300 to 3,100 125 to 150 | 507 to 682 26.2 to 31.8 | 100 |
| SAE 10W | **.880 to .935 | 5,000 to 10,000 | 1,100 to 2,200 | (|
| SAE 20W | **.880 to .935 | 10,000 to 40,000 | 2,200 to 8,800 | (|
| Automobile Transmission Lubricants: SAE 80 | **.880 to .935 | 100,000 max. | 22,000 max. | (|
| SAE 90 | **.880 to .935 | 800 to 1,500 300 to 500 | 173.2 to 324.7 64.5 to 108.2 | 100 |
| SAE 140 | **.880 to .935 | 950 to 2,300 120 to 200 | 205.6 to 507 25.1 to 42.9 | 130 210 |
| SAE 250 | **.880 to .935 | Over 2,300 Over 200 | Over 507 Over 42.9 | 130 |
| AGMA Gear Oils: AGMA No. 1 | .880 to .935 | 180 to 240 45 to 48 | 38.1 to 51.8 9.9 to 10.6 | 100 |
| AGMA No. 2 | .880 to .935 | 275 to 360 50 to 55 | 59.3 to 77.5 11.0 to 12.1 | 100 |
| AGMA No. 3 | .880 to .935 | 490 to 650 63 to 71 | 106 to 140 13.9 to 15.6 | 100 |
| AGMA No. 4 | .880 to .935 | 650 to 1,000 71 to 87 | 140 to 216 15.6 to 19.2 | 100 |
| AGMA No. 5 | .880 to .935 | 875 to 1,350 83 to 105 | 189 to 291 18.4 to 22.3 | 100 |
| AGMA No. 6 | .880 to .935 | 1,350 to 1,850 105 to 125 | 291 to 398 22.3 to 26.5 | 100 |
| AGMA No. 7 | .880 to .935 | 1,850 to 2,500 125 to 150 | 398 to 539 26.5 to 31.9 | 100 |
| AGMA No. 8 | .880 to .935 | 2,500 to 3,700 150 to 190 | 539 to 797 31.9 to 40.2 | 100 |
| AGMA No. 8A | .880 to .935 | 3,700 to 4,700 190 to 215 | 797 to 1,015 40.2 to 45.6 | 100 |

^{*}Unless otherwise noted.

^{**}Depends on origin or percent and type of solvent.

| Limite | *C- C C0°F | VISCOSITY | | |
|--|------------------|----------------------------|----------------------------------|-------------------|
| Liquid | *Sp Gr at 60°F | SSU | Centistokes | At |
| Diesel Engine Lubricating Oils (Based on Average Midcontinent Paraffin Base): Federal Specification No. 9110 | **.880 to .935 | 165 to 240 90 to 120 | 35.4 to 51.9 18.2 to 25.3 | 100 |
| Federal Specification No. 9170 | **.880 to .935 | 300 to 410 140 to 180 | 64.5 to 88.8 29.8 to 38.8 | 100 |
| Federal Specification No. 9250 | **.880 to .935 | 470 to 590 200 to 255 | 101.8 to 127.8 43.2 to 55.1 | 100 |
| Federal Specification No. 9370 | **.880 to .935 | 800 to 1,100 320 to 430 | 173.2 to 238.1 69.3 to 93.1 | 100 |
| Federal Specification No. 9500 | **.880 to .935 | 490 to 600 92 to 105 | 106.1 to 129.9 18.54 to 21.6 | 130 |
| Diesel Fuel Oils: | | 1232 722727 | 19 18 | |
| No. 2D | **.82 to .95 | 32.6 to 45.5 39 | 2 to 6 1 to 3.97 | 100 |
| No. 3D | **.82 to .95 | 45.5 to 65 39 to 48 | 6 to 11.75 3.97 to 6.78 | 100 |
| No. 4D | **.82 to .95 | 140 max. 70 max. | 29.8 max. 13.1 max. | 100 |
| No. 5D | **.82 to .95 | 400 max. 165 max. | 86.6 max. 35.2 max. | 122 |
| Fuel Oils: No. 1 | **.82 to .95 | 34 to 40 32 to 35 | 2.39 to 4.28 2.69 | 70 |
| No. 2 | **.82 to .95 | 36 to 50 33 to 40 | 3.0 to 7.4 2.11 to 4.28 | 70 100 |
| No. 3 | **.82 to .95 | 35 to 45 32.8 to 39 | 2.69 to .584 2.06 to 3.97 | 100 |
| No. 5A | **.82 to .95 | 50 to 125 42 to 72 | 7.4 to 26.4 4.91 to 13.73 | 100 |
| No. 5B | **.82 to .95 | 125 to 400 72 to 310 | 26.4 to 86.6 13.63 to 67.1 | 100 122 130 |
| No. 6 | **.82 to .95 | 450 to 3,000 175 to 780 | 97.4 to 660 37.5 to 172 | 122 |
| Fuel Oil — Navy Specification | **.989 max | 110 to 225 63 to 115 | 23 to 48.6 11.08 to 23.9 | 122 |
| Fuel Oil — Navy II | 1.0 max | 1,500 max. 480 max. | 324.7 max. 104 max. | 122 |
| Gasoline | .68 to .74 | | .46 to .88 .40 to .71 | 100 |
| Gasoline (Natural) | 76.5 degrees API | | .41 | 68 |
| Gas Oil | 28 degrees API | 73 50 | 13.9 7.4 | 70 100 |

^{*}Unless otherwise noted.

^{**}Depends on origin or percent and type of solvent.

| | 10-0-1005 | VISC | | |
|--|---------------|------------------------------|---------------------------------|-----|
| Liquid | *Sp Grat 60°F | SSU | Centistokes | Ato |
| Insulating Oil: Transformer, switches and circuit breakers | | 115 max. 65 max. | 24.1 max. 11.75 max. | 70 |
| Kerosene | .78 to .82 | 35 32.6 | 2.69 2 | 68 |
| Lubricating Oil: ISO 32 | .91 Ave. | 150 85 | 32 17 | 100 |
| ISO 46 | .91 Ave. | 215 115 | 46 24 | 100 |
| ISO 68 | .91 Ave. | 315 150 | 68 32 | 100 |
| ISO 90 | .91 Ave. | 420 195 | 90 42 | 100 |
| ISO 148 | .91 Ave. | 685 280 | 148 60 | 100 |
| Mineral Lard Cutting Oil: Federal Specification Grade 1 | | 140 to 190 86 to 110 | 29.8 to 41 17.22 to 23 | 100 |
| Federal Specification Grade 2 | | 190 to 220 110 to 125 | 41 to 47.5 23 to 26.4 | 100 |
| Petrolatum | .825 | 100 77 | 20.6 14.8 | 130 |
| VEGETABLE OILS: Castor Oil | .96 @ 68 F. | 1,200 to 1,500 450 to 600 | 259.8 to 324.7 97.4 to 129.9 | 100 |
| China Wood Oil | .943 | 1,425 580 | 308.5 125.5 | 69 |
| Cocoanut Oil | .925 | 140 to 148 76 to 80 | 29.8 to 31.6 14.69 to 15.7 | 100 |
| Corn Oil | .924 | 135 54 | 28.7 8.59 | 130 |
| Cotton Seed Oil | .88 to .925 | 176 100 | 37.9 20.6 | 100 |
| Linseed Oil, Raw | .925 to .939 | 143 93 | 30.5 18.94 | 100 |
| Olive Oil | .912 to .918 | 200 115 | 43.2 24.1 | 100 |
| Palm Oil | .920 | 195 112 | 42 23.4 | 100 |
| Peanut Oil | .924 | 221 125 | 47.8 26.4 | 100 |
| Rape Seed Oil | .919 | 250 145 | 54.1 31 | 100 |

^{*}Unless otherwise noted.

| Liquid | *Sp Gr at 60°F | VISCOSITY | | |
|--|----------------|--------------------------------------|-------------------------------------|------------|
| - Ciquid | Sp Gr at 00 P | SSU | Centistokes | At°F |
| Rosin Oil | .980 | 1,500 600 | 324.7 129.9 | 100 130 |
| Rosin (Wood) | 1.09 Avg. | 500 to 20,000 1,000 to 50,000 | 108.2 to 4,400 216.4 to 11,000 | 200 190 |
| Sesame Oil | .923 | 184 110 | 39.6 23 | 100 |
| Soja Bean Oil | .927 to .98 | 165 96 | 35.4 19.64 | 100 130 |
| Turpentine | .86 to .87 | 33 32.6 | 2.11 2.0 | 60 100 |
| SUGAR, SYRUPS, MOLASSES, ETC. Corn Syrups | 1.4 to 1.47 | 5,000 to 500,000 1,500 to 60,000 | 1,100 to 110,000 324.7 to 13,200 | 100 130 |
| Glucose | 1.35 to 1.44 | 35,000 to 100,000 4,000 to 11,000 | 7,700 to 22,000 880 to 2,420 | 100 150 |
| Honey (Raw) | | 340 | 73.6 | 100 |
| Molasses "A" (First) | 1.40 to 1.46 | 1,300 to 23,000 700 to 8,000 | 281.1 to 5,070 151.5 to 1,760 | 100 130 |
| Molasses "B" (Second) | 1.43 to 1.48 | 6,400 to 60,000 3,000 to 15,000 | 1,410 to 13,200 660 to 3,300 | 100 130 |
| Molasses "C" (Blackstrap or final) | 1.46 to 1.49 | 17,000 to 250,000 6,000 to 75,000 | 2,630 to 5,500 1,320 to 16,500 | 100 130 |
| Sucrose Solutions (Sugar Syrups): 60 Brix | 1.29 | 230 92 | 49.7 18.7 | 70 100 |
| 62 Brix | 1.30 | 310 111 | 67.1 23.2 | 70 100 |
| 64 Brix | 1.31 | 440 148 | 95.2 31.6 | 70 100 |
| 66 Brix | 1.326 | 650 195 | 140.7 42.0 | 70 100 |
| 68 Brix | 1.338 | 1,000 275 | 216.4 59.5 | 70 100 |
| 70 Brix | 1.35 | 1,650 400 | 364 86.6 | 70 100 |
| 72 Brix | 1.36 | 2,700 640 | 595 138.6 | 70 100 |
| 74 Brix | 1.376 | 5,500 1,100 | 1,210 238 | 70 100 |
| 76 Brix | 1.39 | 10,000 2,000 | | 70 100 |

^{*}Unless otherwise noted.


^{**}Depends on origin or percent and type of solvent.

| | #0- C+ 00°E | VISCOS | SITY | At°F |
|--|----------------|--------------------------------------|------------------------------------|------------|
| Liquid | *Sp Gr at 60°F | SSU | Centistokes | Atr |
| TARS: Tar-Coke Oven | 1.12+ | 3,000 to 8,000 650 to 1,400 | 600 to 1,760 140.7 to 308 | 71 100 |
| Tar-Gas House | 1.16 to 1.30 | 15,000 to 300,000 2,000 to 20,000 | 3,300 to 66,000 440 to 4,400 | 70 100 |
| Road Tar: Grade RT-2 | 1.07+ | 200 to 300 55 to 60 | 43.2 to 64.9 8.77 to 10.22 | 122 212 |
| Grade RT-4 | 1.08+ | 400 to 700 65 to 75 | 86.6 to 154 11.63 to 14.28 | 122 212 |
| Grade RT-6 | 1.09+ | 1,000 to 2,000 85 to 125 | 216.4 to 440 16.83 to 26.2 | 122 212 |
| Grade RT-8 | 1.13+ | 3,000 to 8,000 150 to 225 | 660 to 1,760 31.8 to 48.3 | 122 212 |
| Grade RT-10 | 1.14+ | 20,000 to 60,000 250 to 400 | 4,400 to 13,200 53.7 to 86.6 | 122 212 |
| Grade RT-12 | 1.15+ | 114,000 to 456,000 500 to 800 | 25,000 to 75,000 108.2 to 173.2 | 122 212 |
| Pine Tar | 1.06 | 2,500 500 | 559 108.2 | 100 132 |
| MISCELLANEOUS: Corn Starch Solutions: 22 Baumé | 1.18 | 150 130 | 32.1 27.5 | 70 100 |
| 24 Baumé | 1.20 | 600 440 | 129.8 95.2 | 70 100 |
| 25 Baumé | 1.21 | 1,400 800 | 303 173.2 | 70 100 |
| Ink — Printers | 1.00 to 1.38 | 2,500 to 10,000 1,100 to 3,000 | 550 to 2,200 238.1 to 660 | 100 |
| Tallow | .918 Avg. | 56 | 9.07 | 212 |
| Milk | 1.02 to 1.05 | | 1.13 | 68 |
| Varnish — Spar | .9 | 1,425 650 | 313 143 | 68 100 |
| Water — Fresh | 1.0 | | 1.13 .55 | 60 130 |

^{*}Unless otherwise noted.

^{**}Depends on origin or percent and type of solvent.

Viscosity Blending Chart



VISCOSITY SECONDS SAYBOLT UNIVERSAL OIL A (THE HIGH VISCOSITY COMPONENT)

Reprinted from Standards of the Hydroutic Institute—Tenth Edition Copyright 1955

At the same temperature, plot viscosity of oil A (high viscosity component) on the right hand scale and oil B (low viscosity component) on the left hand scale. Connect the two points with a straight line. Then read the blend viscosity as a function of percentage of oil A or B.

Newtonian and Non-Newtonian Fluids

Newtonian Materials

Newton deduced that the viscosity of a given liquid should be constant at any particular temperature and pressure and independent of the rate of shear, as illustrated in Fig. 13. In such "Newtonian fluids," shear stress is directly proportional to rate of shear. At temperatures above their cloud points most mineral oils are Newtonian fluids.




Fig. 13. Characteristics of Newtonian liquids. (a) Viscosity is independent of rate of shear. (b) Shear stress is directly proportional to rate of shear.

Non-Newtonian Materials

The viscosities of some materials, such as greases and polymer-thickened mineral oils, are affected by shearing effects, and these materials are termed non-Newtonian. In other words, the viscosity of a non-Newtonian fluid will depend on the rate of shear at which it is measured. Since a non-Newtonian fluid can have an unlimited number of viscosity values (as the shear rate is varied) the term apparent viscosity is used to describe its viscous properties. Apparent viscosity is expressed in absolute units and is a measure of the resistance to flow at a given rate of shear. It has meaning only if the rate of shear used in the measurement is also given and is obtained experimentally by measuring and dividing the shear stress by the rate of shear. A "rheogram" or "flow curve" relating shear stress to rate of shear is frequently used to describe completely the viscous properties of a non-Newtonian material.

Non-Newtonian materials may be divided into five types: plastic, pseudo-plastic, dilatant, thixotropic, and rheopectic. Figure 14 presents characteristic rheograms in which shear stress (e.g., pressure in a steady-flow system) is plotted against rate of shear (e.g., flow velocity). The curves at the left in Fig. 15 illustrate how the apparent viscosities of non-Newtonian materials vary with changing rates of shear.

As illustrated in curve 1 of Fig. 14 a plastic material, such as a grease, putty, or molding clay, is characterized by a "yield point" or "yield value." This means that a definite minimum stress or force must be applied to the material before any flow takes place. From a rheological standpoint, tomato catsup is a common example of a plastic material. If a bottle




Fig. 14. Flow curves illustrating shear characteristics of various types of materials.

is shaken only gently, its contents may not flow out because the "yield point" has not been exceeded. However, if the bottle is struck or shaken more vigorously, the yield point is exceeded, the viscosity is reduced, and the catsup gushes forth.

While a pseudo-plastic fluid has no yield point, its apparent viscosity also decreases with increasing shear rates but stabilizes only at very high rates of shear. Many emulsions such as water-base fluids and resinous materials show this type of behavior.

Oppositely, the apparent viscosity of a dilatant fluid increases as the rate of shear increases. Such a fluid often solidifies at high rates of shear. Examples are pigment-vehicle suspensions such as paints and printing inks, and some starches.

The three fluids described above—plastic, pseudo-plastic, and dilatant—are also known as time-independent non-Newtonian fluids, since their rheological or flow properties are independent of time. The rate of shear at any point in the fluid is a simple function of the shear stress at that point.

On the other hand, the flow properties of two other non-Newtonian materials—thixotropic and rheopectic—are dependent on time. The apparent viscosity of these more complex fluids

¹ Rheology: the science treating of deformation and flow of matter.

depends not only on the magnitude of the shear rate but also on the length of time during which shear has been applied, as illustrated in Fig. 15.

If a thixotropic fluid is subjected to a constant rate of shear for some time, its structure is gradually broken down and its apparent viscosity decreases to some minimum value. When the shear effect is removed and the fluid is at rest, the structure rebuilds gradually and apparent viscosity increases with time to the original value. This is called reversible thixotrophy. If, however, upon removing the shear stress, a value less than the original viscosity is obtained with time, the phenomenon is known as irreversible thixotrophy. Some oils containing high-molecular-weight polymers and mineral oils at temperatures below their cloud point show this latter effect.

During rotary drilling of deep oil wells, a very special "drilling mud" with thixotropic properties is pumped down the hollow drill stem to force cuttings back to the surface. As long as the mud is agitated by rotation of the drill stem and by pumping, it remains fluid and removes drilling debris. However, whenever drilling is stopped, the drilling mud solidifies to a gel, holds the cuttings in suspension, and thereby

for a time, its apparent viscosity decreases again.

Some greases are intentionally manufactured to have partial rheopectic properties, which facilitate pumping from a drum or central grease storage in which the grease is in a relatively fluid condition. Upon shearing in a bearing, however, the grease builds up to a higher apparent viscosity or consistency and stays in place. Such a grease does not have full rheopectic characteristics, however, since after shearing and resting, it still retains a higher consistency.

Since the viscosity of a non-Newtonian lubricant is dependent upon the rate of shear acting on it, the importance of measuring viscosity at various shear rates that will be encountered in the use of such a lubricant can be readily seen. In some machine elements, shear rates up to 3 million reciprocal seconds may be encountered, while in other applications only a few reciprocal seconds or a few tenths are the order of magnitude. In dispensing greases, shear rates as low as 0.1 reciprocal second are sometimes encountered, while leakage from housings during periods of shutdowns involves an even lower range.




Fig. 15. Different types of non-Newtonian behavior.





Fig. 16. Viscosity vs. rate of shear for Newtonian and non-Newtonian oils.

prevents them from settling and interfering with subsequent drilling.

Quicksand is also thixotropic, since it becomes more and more fluid when agitated; therefore anyone caught in this water-and-sand mixture improves his chance of survival by remaining as motionless as possible.

If a rheopectic fluid is subjected to a constant rate of shear for a given period of time, its apparent viscosity increases to some maximum value. Upon cessation of shearing and resting As illustrated by Fig. 16, the determination of viscosity of a non-Newtonian liquid at only one shear rate is not usually sufficient. Incorrect conclusions would be drawn and application difficulties would be invited if the viscosities of a Newtonian and a non-Newtonian oil were measured at some specific shear rate R_0 , where the two curves happened to cross each other. While both oils have the same apparent viscosity at this one point, the remainders of their viscosity-shear curves are entirely different.

Typical Shear Rate Curves



Reprinted from Standards of the Hydraulic Institute—Tenth Edition Capyright 1955

Conversion Data

ENGLISH SYSTEM

| To convert | Multiply by | To obtain |
|------------|-------------|------------|
| To obtain | Divide by | To convert |

UNITS OF LENGTH

| yd. | 36 | in. |
|---------------|----------|-------|
| yd. | 3 | ft. |
| yd. | 0.000568 | miles |
| miles | 63.360 | in. |
| miles | 5.280 | ft. |
| miles | 1,760 | vd. |
| miles (naut.) | 6,076 | ft. |

UNITS OF AREA

| sq. yd. | 9 | sq. ft. |
|---------|-----------|---------|
| sq. yd. | 0.0002066 | acres |
| acres | 43,560 | sq. ft. |
| acres | 4.840 | sq. yd. |
| sq. yd. | 1,296 | sq. in. |

UNITS OF VOLUME

| cu. in. | 0.00433 | gal. |
|---------|------------|--------------|
| cu. in. | 0.000579 | cu. ft. |
| cu. in. | 0.0000214 | cu. yd. |
| gal. | 231 | cu. in. |
| gal. | 0.1337 | cu. ft. |
| gal. | 0.00495 | cu. yd. |
| gal. | 0.00000307 | acre-ft. |
| gal. | 0.0238 | bbl (oil) |
| gal. | 0.8327 | Imperial gal |
| cu. ft. | 1,728 | cu. in. |
| cu. ft. | 7.48 | gal. |

UNITS OF WEIGHT

| 0.0001429 | lb. |
|--------------|---------------------------------------|
| 0.0000000044 | |
| 0.0000000714 | tons |
| 438 | grains |
| 0.0625 | lb. |
| 0.00003125 | tons |
| 8.3322 | lb.* |
| 0.12002 | gal,* |
| | 438 0.0625 0.00003125 8.3322 |

VOLUME - FLOW RATES

| gps | 8.022 | cfm |
|----------------|-----------|-------------|
| gps | 481.3 | cu. ft./hr. |
| gps | 60 | gpm |
| gps | 3,600 | gal./hr. |
| gpm | 0.00223 | cfs |
| gpm | 0.1337 | cfm |
| gpm | 8.022 | cu. ft./hr. |
| gpm | 0.01667 | gps |
| gpm | 60 | gal./hr. |
| gpm | 499.925 | lb./hr.* |
| gal./hr. | 0.0000371 | cfs |
| gal./hr. | 0.00223 | cfm |
| gal./hr. | 0.1337 | cu. ft./hr. |
| gal./hr. | 0.0002778 | gps |
| gal./hr. | 0.01667 | gpm |
| bbl/min. (oil) | 42 | gpm |
| bbl/day (oil) | 0.0292 | gpm |

METRIC SYSTEM

| To convert | Multiply by | To obtain |
|------------|-------------|------------|
| To obtain | Divide by | To convert |

UNITS OF LENGTH

| cm | 0.3937 | in. |
|--------|---------|-------|
| meters | 39.37 | in. |
| meters | 3.281 | ft. |
| meters | 1.0936 | vd. |
| km | 3,281 | ft. |
| km | 1,093.6 | vd. |
| km | 0.6214 | miles |

UNITS OF AREA

| sq. mm | 0.00155 | sq. in. |
|------------|---------|-----------|
| sq. cm | 0.155 | sq. in. |
| sq. meters | 10.764 | sq. ft. |
| sq. meters | 1.196 | sq. yd. |
| sq. km | 0.3861 | sq. miles |

UNITS OF VOLUME

| cu. cm cu. cm | 0.06102 0.03381 | fl. oz. |
|----------------------|--------------------|---------|
| cu. meters | 35.31 | cu. ft. |
| cu. meters | 1.308 | cu. yd. |
| cu. meters liters | 264.2 61.02 | US gal. |
| liters | 0.03531 | cu. ft. |
| liters | 0.2642 | US gal. |

UNITS OF WEIGHT

| grams | 15.43 | grains |
|--------|----------|---------|
| grams | 0.0353 | OZ. |
| kg | 35.27 | oz. |
| kg | 2.2046 | lb. |
| kg | 0.001102 | US tons |
| tonnes | 2,204.6 | lb. |
| tonnes | 1.1023 | US tons |

VOLUME - FLOW RATES

| liters/sec. | 15.85 | US gpm |
|-------------|---------|--------|
| liters/min. | 0.2642 | US gpm |
| liters/min. | 0.03531 | cfm |
| liters/hr. | 0.0044 | US gpm |
| cu. m/min. | 35.314 | cfm |
| cu. m/min. | 264.17 | US gpm |
| cu. m/hr. | 0.5883 | cfm |
| cu. m/hr. | 4.4028 | US gpm |
| | | |

Conversion Data

ENGLISH SYSTEM

| To convert | Multiply by | To obtain |
|------------|-------------|------------|
| To obtain | Divide by | To convert |

UNITS OF PRESSURE (Water at 68° F)

| in. water | 0.0833 | ft. water |
|----------------|----------------|-------------|
| in. water | 0.0736 | in. mercury |
| in. water | 82.98 | oz./sq. ft. |
| in, water | 0.03602 | psi |
| in. water | 5.1869 | psf |
| ft. water | 12 | in. water |
| ft. water | 0.8832 | in. mercury |
| ft. water | 995.8 | oz./sq. ft. |
| ft. water | 0.4322 | psi |
| ft. water | 62.24 | psf |
| ft. (any liq.) | 0.4322 x sp gr | psi |
| in. mercury | 13.57 | in. water |
| in. mercury | 1.131 | ft. water |
| in, mercury | 1128 | oz./sq. ft. |
| in. mercury | 0.4894 | psi |
| in. mercury | 70.47 | psf |
| in, mercury | 0.03342 | atm |
| atm | 29.92 | in, mercury |

UNITS OF WORK, ENERGY & HEAT

| 9,340 | inlb. |
|---------------|--|
| 778.3 | ftlb. |
| 0.000293 | kwhr. |
| 0.000393 | hp-hr. |
| 0.000107 | Btu |
| 0.0833 | ftlb. |
| 0.00000003138 | kwhr. |
| 0.0000000421 | hp-hr. |
| 0.001285 | Btu |
| 12 | inlb. |
| | 778.3 0.000293 0.000393 0.000107 0.0833 0.00000003138 0.0000000421 0.001285 |

UNITS OF POWER

| kw | 1.341 | hp |
|------------|----------|------------|
| kw | 738 | ftlb./sec. |
| kw | 44,260 | ftlb./min. |
| kw | 0.948 | Btu/sec. |
| kw | 56.9 | Btu/min. |
| kw | 3,413 | Btu/hr. |
| hp | 0.7455 | kw |
| hp | 550 | ftlb./sec. |
| hp | 33.000 | ftlb./min. |
| hp | 0.707 | Btu/sec. |
| hp | 42.41 | Btu/min. |
| hp | 2,545 | Btu/hr. |
| ftlb./sec. | 0.001356 | kw |
| ftlb./sec. | 0.001818 | hp |
| ftlb./sec. | 60 | ftlb./min. |
| ftlb./sec. | 0.001285 | Btu/sec. |

METRIC SYSTEM

| To convert | Multiply by | To obtain |
|------------|-------------|------------|
| To obtain | Divide by | To convert |

UNITS OF PRESSURE (hg. @ 68°F)

| gr/sq. cm | 0.01422 | psi |
|--------------|--------------|-------------|
| gr/cu. cm | 0.0361 | lb./cu. in. |
| kg/sq. cm | 14.22 | psi |
| kg/cu. m | 0.0624 | lb./cu. ft. |
| kg/m | 0.6720 | lb./ft. |
| meters water | 1.42 | psi |
| meters | | |
| (any lig.) | 1.42 x sp gr | psi |
| mm mercury | 0.001316 | atm |
| mm mercury | 1000 | microns |

UNITS OF WORK, ENERGY & HEAT

| gr-cal | 0.003969 | Btu |
|---------------|-----------|------------|
| kg-cal | 3.9693 | Btu |
| kg-cal/kg | 1.800 | Btu/lb. |
| gr-cal/sq. cm | 3.687 | Btu/sq. ft |
| kg-cal/cu. m | 0.1124 | Btu/cu, ft |
| ioule | 0.7376 | ftlb. |
| meter-kg | 7.2330 | ftlb. |
| gr-cal | 3.087 | ftlb. |
| kg-cal | 3,087 | ftlb. |
| hp-hr. | 1,980,000 | ftlb. |
| kwhr. | 2,655,000 | ftlb. |
| Btu | 778.3 | ftlb. |

UNITS OF POWER

| watts | 0.7376 | ftlb./sec. |
|------------|----------|------------|
| watts | 0.001341 | hp |
| kw | 1.3410 | hp |
| cheval-vap | 0.9863 | hp |

FORMULAS

| TEMPERATURE | °C = 5/9 (°F-32) °F = 9/5 °C+32 |
|----------------|--|
| A.P.I. GRAVITY | Sp. Gr. = 141.5 131:5 + °A.P.I. |
| POWER | $HP = \frac{T \times RPM}{5252}$ (Torque in foot-pounds) |

Equivalent Values of Pressure

| In. Hg. | PSI | Ft. (S.G.=10) | (S.G.=0.9) |
|---|---|--|--|
| 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 26 27 28 29 29 20 20 20 20 20 20 20 20 20 20 20 20 20 | .489 979 1.47 1.96 2.45 2.94 3.92 4.40 4.89 5.87 6.36 6.85 7.34 7.83 8.32 8.81 9.30 9.79 10.8 11.2 11.7 12.7 13.7 14.7 | 1.13 2.26 3.39 4.52 5.66 6.79 7.92 9.05 10.2 11.3 12.4 13.6 14.7 15.8 17.0 18.1 19.2 20.4 21.5 22.6 23.8 24.9 26.0 27.1 28.3 29.4 30.5 31.7 32.8 33.9 | 1.26 2.51 3.77 5.03 6.28 7.54 8.80 10.0 11.3 12.6 13.8 15.1 16.3 17.6 18.8 20.1 21.4 22.6 23.9 25.1 26.4 27.6 28.9 30.2 31.4 32.7 33.9 35.2 36.4 37.7 |

| (S.G.=1.0) | In. Hg. | PSI | (S.G.=0.9) |
|---|---|---|---|
| 1 2 3 4 5 6 7 8 9 10 15 20 25 30 35 40 45 50 60 70 80 90 150 200 250 250 500 750 100 150 200 200 200 200 200 200 200 200 200 2 | 0.883 1.77 2.65 3.53 4.42 5.30 6.18 7.06 7.95 8.83 13.2 17.7 22.1 26.5 30.9 35.3 39.7 44.2 53.0 61.8 70.6 79.5 88.3 13.2 17.7 22.1 44.2 66.2 88.3 | 0.432 0.864 1.30 1.73 2.16 2.59 3.02 3.46 3.89 4.32 6.48 8.64 10.8 13.0 15.1 17.3 19.4 21.6 25.9 30.2 34.6 38.9 4.32 64.8 86.4 108 | 1.11 2.22 3.33 4.44 5.56 6.67 7.78 8.89 10.0 11.1 18.7 22.2 27.8 33.3 37.8 44.4 50.0 55.6 66.7 77.8 88.9 100 111 167 222 278 83.9 |

| | Pounds per square inch | | | | |
|---|---|--|---|--|--|
| PSI | In, Hg. | (S.G.=1.0) | Ft. (S.G.=0.9) | | |
| 1 2 3 4 5 6 6 7 8 9 10 15 20 25 30 35 40 45 50 60 70 80 90 150 250 250 250 250 250 250 250 250 250 2 | 2.04 4.09 6.13 8.17 10.2 12.2 14.3 16.3 18.4 20.4 30.6 40.9 51.1 61.3 71.5 81.7 91.9 102 122 143 163 184 204 306 409 51.1 1021 1121 1132 1131 1131 1131 1131 113 | 2.31 4.63 6.94 9.25 11.6 13.9 16.2 18.5 20.8 23.1 34.7 46.3 57.8 69.4 81.0 92.5 104 116 139 162 185 208 231 347 463 578 | 2.57 5.14 7.71 10.3 12.8 15.4 18.0 20.6 23.1 25.7 38.6 51.4 64.3 77.1 90.0 103 116 128 154 180 206 231 257 386 51.4 64.3 1285 51.4 64.3 | | |

| | Feet of 0.9 | S.G. Liquid | |
|---|--|---|---|
| Ft. (S.G.=0.9) | In. Hg. | PSI | (S.G.=1.0) |
| 1 2 3 4 5 6 6 7 8 9 10 15 20 25 30 35 40 45 50 60 70 80 90 150 250 500 500 500 500 500 500 500 500 5 | 0.794 1.59 2.38 3.18 3.97 4.77 5.56 6.36 7.15 7.95 11.9 15.9 19.9 23.8 27.8 31.8 35.8 35.8 39.7 47.7 55.6 63.6 71.5 79.5 119 159 199 397 596 795 | 0.389 0.778 1.17 1.56 1.94 2.33 2.72 3.11 3.50 3.89 5.83 7.78 9.72 11.7 13.6 15.6 17.5 19.4 23.3 27.2 31.1 35.0 38.9 58.3 77.8 97.2 194 292 389 | 0.900 1.80 2.70 3.60 4.50 5.40 6.30 7.20 8.10 9.00 13.5 18.0 22.5 27.0 31.5 36.0 40.5 45.0 54.0 63.0 72.0 81.0 90.0 135 180 225 450 675 900 |

Properties of the Lower Atmosphere

| Altitude, ft. | Pressure, | Pressure, in. Hg at 32° F. | Specific wt, lb./cu. ft. | Temp.,°F |
|------------------|-----------|----------------------------------|-----------------------------|----------|
| 0 | 14.696 | 29.921 | 0.07648 | 59.0 |
| 100 | 14.64 | 29.81 | 0.0763 | 58.6 |
| 200 | 14.59 | 29.71 | 0.0760 | 58.3 |
| 300 | 14.54 | 29.60 | 0.0758 | 57.9 |
| 400 | 14.48 | 29.49 | 0.0756 | 57.6 |
| 500 | 14.43 | 29.38 | 0.0754 | 57.2 |
| 600 | 14.38 | 29.28 | 0.0751 | 56.9 |
| 700 | 14.33 | 29.17 | 0.0749 | 56.5 |
| 800 | 14.28 | 29.07 | 0.0747 | 56.1 |
| 900 | 14.22 | 28.96 | 0.0745 | 55.8 |
| 1,000 | 14.17 | 28.86 | 0.0743 | 55.4 |
| 1,100 | 14.12 | 28.75 | 0.0740 | 55.1 |
| 1,200 | 14.07 | 28.65 | 0.0738 | 54.7 |
| 1,300 | 14.02 | 28.54 | 0.0736 | 54.4 |
| 1,400 | 13.97 | 28.44 | 0.0734 | 54.0 |
| 1,500 | 13.92 | 28.33 | 0.0732 | 53.7 |
| 1,600 | 13.87 | 28.23 | 0.0730 | 53.3 |
| 1,700 | 13.82 | 28.13 | 0.0727 | 52.9 |
| 1,800 | 13.76 | 28.02 | 0.0725 | 52.6 |
| 1,900 | 13.71 | 27.92 | 0.0723 | 52.2 |
| 2,000 | 13.66 | 27.82 | 0.0721 | 51.9 |
| 2,200 | 13.56 | 27.62 | 0.0717 | 51.2 |
| 2,400 | 13.47 | 27.42 | 0.0712 | 50.4 |
| 2,600 | 13.37 | 27.21 | 0.0708 | 49.7 |
| 2,800 | 13.27 | 27.02 | 0.0704 | 49.0 |
| 3,000 | 13.17 | 26.82 | 0.0700 | 48.3 |
| 3,500 | 12.93 | 26.33 | 0.0689 | 46.5 |
| 4,000 | 12.69 | 25.84 | 0.0679 | 44.7 |
| 4,500 | 12.46 | 25.37 | 0.0669 | 43.0 |
| 5,000 | 12.23 | 24.90 | 0.0659 | 41.2 |
| 6,000 | 11.78 | 23.98 | 0.0639 | 37.6 |
| 7,000 | 11.34 | 23.09 | 0.0620 | 34.0 |
| 8,000 | 10.92 | 22.22 | 0.0601 | 30.5 |
| 9,000 | 10.50 | 21.39 | 0.0583 | 26.9 |
| 10,000 | 10.11 | 20.58 | 0.0565 | 23.3 |
| 12,000 | 9.346 | 19.03 | 0.0530 | 16.2 |
| 14,000 | 8.633 | 17.58 | 0.0497 | 9.1 |
| 15,000 | 8.293 | 16.89 | 0.0481 | 5.5 |
| 16,000 | 7.965 | 16.21 | 0.0466 | 1.9 |
| 18,000 | 7.339 | 14.94 | 0.0436 | - 5.2 |
| 20,000 | 6.753 | 13.75 | 0.0407 | -12.3 |
| 25,000 | 5.453 | 11.10 | 0.0343 | -30.2 |
| 30,000 | 4.364 | 8.885 | 0.0286 | -48.0 |
| 35,000 | 3.458 | 7.041 | 0.0237 | -65.8 |
| 40,000 | 2.720 | 5.538 | 0.0188 | -69.7 |
| 45,000 | 2.139 | 4.355 | 0.0148 | -69.7 |
| 50,000 | 1.682 | 3.425 | 0.0116 | -69.7 |
| 55,000 | 1.323 | 2.693 | 0.00915 | -69.7 |
| 60,000 | 1.040 | 2.118 | 0.00720 | -69.7 |
| 65,000 | 0.8180 | 1.665 | 0.00566 | -69.7 |

Data from NASA Standard Atmosphere (1962).

ANSI Standard Steel Pipe Flanges

| Nominal pipe size | Flange OD | Flange thickness | Bolt circle dia. | Bore weld neck socket weld† | No. of bolts | Bolt dia. | Nominal pipe size | Flange OD | Flange thickness | Bolt circle dia. | Bore weld neck socket weld | No. of bolts | Bolt dia. |
|-------------------|--------------|---------------------|------------------------|-----------------------------------|-----------------|--------------|-------------------|--------------|---------------------|------------------------|----------------------------------|-----------------|--------------|
| | | 150- | lb. Stand | lard* | | | | | 900 | lb. Stand | lard § | | |
| 1/2 | 3-1/2 | 7/16 | 2-3/8 | 0.62 | 4 | 1/2 | 1/2 | 4-3/4 | 7/8 | 3-1/4 | Ť | 4 | 3/4 |
| 3/4 | 3-7/8 | 1/2 | 2-3/4 | 0.82 | 4 | 1/2 | 3/4 | 5-1/8 | 1 | 3-1/2 | + | 4 | 3/4 |
| 1 | 4-1/4 | 9/16 | 3-1/8 | 1.05 | 4 | 1/2 | 1 | 5-7/8 | 1-1/8 | 4 | + | 4 | 7/8 |
| 1-1/4 | 4-5/8 | 5/8 | 3-1/2 | 1.38 | 4 | 1/2 | 1-1/4 | 6-1/4 | 1-1/8 | 4-3/8 | + | 4 | 7/8 |
| 1-1/2 | 5 | 11/16 | 3.7/8 | 1.61 | 4 | 1/2 | 1-1/2 | 7 | 1-1/4 | 4-7/8 | + | 4 | 1 |
| 2 | 6 | 3/4 | 4-3/4 | 2.07 | 4 | 5/8 | 2 | 8-1/2 | 1-1/2 | 6-1/2 | 1 | 8 | 7/8 |
| 2-1/2 | 7 | 7/8 | 5-1/2 | 2.47 | 4 | 5/8 | 2-1/2 | 9-5/8 | 1-5/8 | 7-1/2 | † | 8 | 1 |
| 3 | 7-1/2 | 15/16 | 6 | 3.07 | 4 | 5/8 | 3 | 10-1/2 | 1-1/2 | 7-1/2 | † | 8 | 7/8 |
| 3-1/2 | 8-1/2 | 15/16 | 7 | 3.55 | 8 | 5/8 | 4 | 11-1/2 | 1-3/4 | 9-1/4 | Ť | 8 | 1-1/8 |
| 4 | 9 | 15/16 | 7-1/2 | 4.03 | 8 | 5/8 | 5 | 13-3/4 | 2 | 11 | 1 | 8 | 1-1/4 |
| 5 | 10 | 15/16 | 8-1/2 | 5.05 | 8 | 3/4 | 6 | 15 | 2-3/16 | 12-1/2 | 1 | 12 | 1-1/8 |
| 6 | 11 | 1 | 9-1/2 | 6,07 | 8 | 3/4 | 8 | 18-1/2 | 2-1/2 | 15-1/2 | Ť | 12 | 1-3/8 |
| 8 | 13-1/2 | 1-1/8 | 11-3/4 | 7.98 | 8 | 3/4 | 10 | 21-1/2 | 2-3/4 | 18-1/2 | 1 | 16 | 1-3/8 |
| 10 | 16 | 1-3/16 | 14-1/4 | 10.02 | 12 | 7/8 | 12 | 24 | 3-1/8 | 21 | + | 20 | 1-3/8 |
| 12 | 19 | 1-1/4 | 17 | 12.00 | 12 | 7/8 | 8700 | 10000 | 90,000,000 | 52556 | | 010502 | 1125-2222 |
| | | 300- | lb. Stand | ard* | | | | | 1,50 | 0 lb. Stan | dard § | | |
| 1/2 | 3-3/4 | 9/16 | 2-5/8 | 0.62 | 4 | 1/2 | 1/2 | 4-3/4 | 7/8 | 3-1/4 | † | 4 | 3/4 |
| 3/4 | 4-5/8 | 5/8 | 3-1/4 | 0.82 | 4 | 5/8 | 3/4 | 5-1/8 | 1 | 3-1/2 | 1 | 4 | 3/4 |
| 1 | 4-7/8 | 11/16 | 3-1/2 | 1.05 | 4 | 5/8 | 1 | 5-7/8 | 1-1/8 | 4 | † | 4 | 7/8 |
| 1-1/4 | 5-1/4 | 3/4 | 3-7/8 | 1,38 | 4 | 5/8 | 1-1/4 | 6-1/4 | 1-1/8 | 4-3/8 | † | 4 | 7/8 |
| 1-1/2 | 6-1/8 | 13/16 | 4-1/2 | 1.61 | 4 | 3/4 | 1-1/2 | 7 | 1-1/4 | 4-7/8 | † | 4 | 1 |
| 2 | 6-1/2 | 7/8 | 5 | 2.07 | 8 | 5/8 | 2 | 8-1/2 | 1-1/2 | 6-1/2 | † | 8 | 7/8 |
| 2-1/2 | 7-1/2 | 1 | 5-7/8 | 2.47 | 8 | 3/4 | 2-1/2 | 9-5/8 | 1-5/8 | 7-1/2 | † | 8 | 1 |
| 3 | 8-1/4 | 1-1/8 | 6-5/8 | 3.07 | 8 | 3/4 | 3 | 10-1/2 | 1-7/8 | 8 | + | 8 | 1-1/8 |
| 3-1/2 | 9 | 1-3/16 | 7-1/4 | 3.55 | 8 | 3/4 | 4 | 12-1/4 | 2-1/8 | 9-1/2 | t | 8 | 1-1/4 |
| 4 | 10 | 1-1/4 | 7-7/8 | 4.03 | 8 | 3/4 | 5 | 14-3/4 | 2-7/8 | 11-1/2 | t | 8 | 1-1/2 |
| 5 | 11 | 1-3/8 | 9-1/4 | 5.05 | 8 | 3/4 | 6 | 15-1/2 | 3-1/4 | 12-1/2 | t | 12 | 1-3/8 |
| 6 | 12-1/2 | 1-7/16 | 10-5/8 | 6.07 | 12 | 3/4 | 8 | 19 | 3-5/8 | 15-1/2 | t | 12 | 1-5/8 |
| 8 | 15 | 1-5/8 | 13 | 7.98 | 12 | 7/8 | 10 | 23 | 4-1/4 | 19 | t | 12 | 1-7/8 |
| 10 | 17-1/2 | 1-7/8 | 15-1/4 | 10.02 | 16 | 1 | 12 | 26-1/2 | 4-7/8 | 22-1/2 | + | 16 | 2 |
| 12 | 20-1/2 | 2 | 17-3/4 | 12.00 | 16 | 1-1/8 | 2555 | 0808484 | \$1.1675,750 | ASSUMMEN | | 7458 | 07 |
| | | 600- | b. Stand | ard § | | | | | 2,50 | 0-lb. Stan | dard § | | |
| 1/2 | 3-3/4 | 9/16 | 2-5/8 | Ť | 4 | 1/2 | 1/2 | 5-1/4 | 1-3/16 | 3-1/2 | + | 4 | 3/4 |
| 3/4 | 4-5/8 | 5/8 | 3-1/4 | † | 4 | 5/8 | 3/4 | 5-1/2 | 1-1/4 | 3-3/4 | Ť | 4 | 3/4 |
| 1 | 4-7/8 | 11/16 | 3-1/2 | t | 4 | 5/8 | 1 | 6-1/4 | 1-3/8 | 4-1/4 | † | 4 | 7/8 |
| 1-1/4 | 5-1/4 | 13/16 | 3-7/8 | t | 4 | 5/8 | 1-1/4 | 7-1/4 | 1-1/2 | 5-1/8 | t | 4 | 1 |
| 1-1/2 | 6-1/8 | 7/8 | 4-1/2 | Ť | 4 | 3/4 | 1-1/2 | 8 | 1-3/4 | 5-3/4 | t | 4 | 1-1/8 |
| 2 | 6-1/2 | 1 | 5 | t | 8 | 5/8 | 2 | 9-1/4 | 2 | 6-3/4 | t | 8 | 1 |
| 2-1/2 | 7-1/2 | 1-1/8 | 5-7/8 | t | 8 | 3/4 | 2-1/2 | 10-1/2 | 2-1/4 | 7-3/4 | Ť | 8 | 1-1/8 |
| 3 | 8-1/4 | 1-1/4 | 6-5/8 | t | 8 | 3/4 | 3 | 12 | 2-5/8 | 9 | t | 8 | 1-1/4 |
| 3-1/2 | 9 | 1-3/8 | 7-1/4 | Ť | 8 | 7/8 | 4 | 14 | 3 | 10-3/4 | Ť | 8 | 1-1/2 |
| 4 | 10-3/4 | 1-1/2 | 8-1/2 | t | 8 | 7/8 | 5 | 16-1/2 | 3-5/8 | 12-3/4 | Ť | 8 | 1-3/4 |
| 5 | 13 | 1-3/4 | 10-1/2 | Ť | 8 | 1 | 6 | 19 | 4-1/4 | 14-1/2 | Ť | 8 | 2 |
| 6 | 14 | 1-7/8 | 11-1/2 | † | 12 | 1 | 8 | 21-3/4 | 5 | 17-1/4 | † | 12 | 2 |
| 8 | 16-1/2 | 2-3/16 | 13-3/4 | Ť | 12 | 1-1/8 | 10 | 26-1/2 | 6-1/2 | 21-1/4 | † | 12 | 2-1/2 |
| 10 | 20 | 2-1/2 | 17 | t | 16 | 1-1/4 | 12 | 30 | 7-1/4 | 24-3/8 | † | 12 | 2-3/4 |
| 12 | 22 | 2-5/8 | 19-1/4 | † | 20 | 1-1/4 | J | | | 5 - 7 | | | |

From ANSI Standard, Steel Pipe Flanges and Flanged Fittings, B16.5-1968.

Flange thickness includes 1/16-in, raised face.

[†] To be specified by purchaser.

[§] Flange thickness does not include 1/4-in, raised face.

ANSI Standard Cast-Iron Pipe Flanges

ANSI Standard Pipe Threads

| Nominal pipe size | Flange OD | Flange thickness | Bolt circle dia | No. of bolts | Bolt |
|-------------------|-----------|---------------------|-----------------------|-----------------|-------|
| | | 125-lb. Stand | dard | | |
| 1 | 4-1/4 | 7/16 | 3-1/8 | 4 | 1/2 |
| 1-1/4 | 4-5/8 | 1/2 | 3-1/2 | 4 | 1/2 |
| 1-1/2 | 5 | 9/16 | 3-7/8 | 4 | 1/2 |
| 2 | 6 | 5/8 | 4-3/4 | 4 | 5/8 |
| 2-1/2 | 7 | 11/16 | 5-1/2 | 4 | 5/8 |
| 3 | 7-1/2 | 3/4 | 6 | 4 | 5/8 |
| 3-1/2 | 8-1/2 | 13/16 | 7 | 8 | 5/8 |
| 4 | 9 | 15/16 | 7-1/2 | 8 | 5/8 |
| 5 | 10 | 15/16 | 8-1/2 | 8 | 3/4 |
| 6 | 11 | 1 | 9-1/2 | 8 | 3/4 |
| 8 | 13-1/2 | 1-1/8 | 11-3/4 | 8 | 3/4 |
| 10 | 16 | 1-3/16 | 14-1/4 | 12 | 7/8 |
| 12 | 19 | 1-1/4 | 17 | 12 | 7/8 |
| | | 250-1b. Stand | lard* | | |
| 1 | 4-7/8 | 11/16 | 3-1/2 | 4 | 5/8 |
| 1-1/4 | 5-1/4 | 3/4 | 3-7/8 | 4 | 5/8 |
| 1-1/2 | 6-1/8 | 13/16 | 4-1/2 | 4 | 3/4 |
| 2 | 6-1/2 | 7/8 | 5 | 8 | 5/8 |
| 2-1/2 | 7-1/2 | 1 | 5-7/8 | 8 | 3/4 |
| 3 | 8-1/4 | 1-1/8 | 6-5/8 | 8 | 3/4 |
| 3-1/2 | 9 | 1-3/16 | 7-1/4 | 8 | 3/4 |
| 4 | 10 | 1-1/4 | 7-7/8 | 8 | 3/4 |
| 5 | 11 | 1-3/8 | 9-1/4 | 8 | 3/4 |
| 6 | 12-1/2 | 1-7/16 | 10-5/8 | 12 | 3/4 |
| 8 | 15 | 1-5/8 | 13 | 12 | 7/8 |
| 10 | 17-1/2 | 1-7/8 | 15-1/4 | 16 | 1 |
| 12 | 20-1/2 | 2 | 17-3/4 | 16 | 1-1/8 |

| Nominal pipe size | Pipe OD | Threads per inch | Length of effective threads | Length of hand-tight engagement | Total thread length |
|-------------------------|---------|------------------|-----------------------------|---------------------------------------|---------------------------|
| 1/16 | 0.3125 | 27 | 0.26 | 0.16 | 0.39 |
| 1/8 | 0.405 | 27 | 0.26 | 0.16 | 0.39 |
| 1/4 | 0.540 | 18 | 0.40 | 0.23 | 0.60 |
| 3/8 | 0.675 | 18 | 0.41 | 0.24 | 0.60 |
| 1/2 | 0.840 | 14 | 0.53 | 0.32 | 0.78 |
| 3/4 | 1.050 | 14 | 0.55 | 0.34 | 0.79 |
| 1 | 1.315 | 11-1/2 | 0.68 | 0.40 | 0.99 |
| 1-1/4 | 1.660 | 11-1/2 | 0.71 | 0.42 | 1.01 |
| 1-1/2 | 1.900 | 11-1/2 | 0.72 | 0.42 | 1.03 |
| 2 | 2.375 | 11-1/2 | 0.76 | 0.44 | 1.06 |
| 2-1/2 | 2.875 | 8 | 1.14 | 0.68 | 1.57 |
| 3 | 3.500 | 8 | 1.20 | 0.77 | 1.63 |
| 3-1/2 | 4.000 | 8 | 1.25 | 0.82 | 1.68 |
| 4 | 4.500 | 8 | 1.30 | 0.84 | 1.73 |
| 5 | 5.563 | 8 | 1.41 | 0.94 | 1.84 |
| 6 | 6.625 | 8 | 1.51 | 0.96 | 1.95 |
| 8 | 8.625 | 8 | 1.71 | 1.06 | 2.15 |
| 10 | 10.750 | 8 | 1.93 | 1.21 | 2.36 |
| 12 | 12.750 | 8 | 2.13 | 1.36 | 2.56 |

Table abridged from ANSI Standard B2.1-1968.

From ANSI Standard, Cast-Iron Pipe Flanges and Flange Fittings. B16.1—1967.

Maximum Non-Shock Hydraulic Working Pressure

| T | | | | Working Pr | ressure PSI | | | |
|------------|------|------|------|------------|-------------|------|-------|-------|
| Temp. | 125# | 150# | 250# | 300# | 600# | 900# | 1500# | 2500# |
| -20 to 100 | 200 | 285 | 500 | 740 | 1480 | 2220 | 3705 | 6170 |
| 200 | 190 | 260 | 460 | 675 | 1350 | 2025 | 3375 | 5625 |
| 300 | 165 | 230 | 375 | 655 | 1315 | 1970 | 3280 | 5470 |
| 400 | 140 | 200 | 290 | 635 | 1270 | 1900 | 3170 | 5280 |
| 500 | | 170 | _ | 600 | 1200 | 1795 | 2995 | 4990 |
| 600 | | 140 | | 550 | 1095 | 1640 | 2735 | 4560 |

NOTES: 125# and 250# from A.N.S.I. B16.1-1989 for ASTM A126, Class B, 1-12" size. Others from A.N.S.I. B16.5-1988 for ASTM A105.

^{*}Flange thickness includes 1/16-in. raised face.

Properties of Welded and Seamless Steel Pipe

| | External | sq.ft/ft | 1.178 | | | | 1,456 | | | | | 1,734 | | | | 2.258 | | | | | | | | | 2.814 | | | | | | | | 3.338 | | | | | | | | |
|--|-----------|-------------------------|--------|---------|--------|---------|--------|----------|--------|---------|--------|--------|--|---|--------|--------|---|--------|-------|---------|--------|-------|-------|---------|--------|----------|------------|---------|-------|-------|---------------|--------|--------|----------|----------------|--------|--------|---|--------|--------|--------|
| | Wt. of | water, lb/ft | 5.51 | 4.98 | 4.47 | 3.38 | 8.66 | 7.87 | 7.08 | 6.32 | 5.62 | 12.5 | 5.01 | 000 | 8.1 | 22.5 | 22.2 | 21.6 | 20.8 | 0.0 | 17.6 | 16.7 | 16.1 | 15.8 | 35.9 | 35.0 | 34.1 | 32.3 | 29.5 | 27.9 | 26.1 | 24.6 | 51.3 | 49.7 | 48.5 | 46.9 | 46.0 | 44.0 | 41.6 | 39.3 | 34.9 |
| | 1014/20 | Ib Ib | 10.79 | 14.98 | 22 52 | 27.54 | 14.62 | 20.78 | 27.04 | 32.96 | 38.55 | 18.97 | 36.47 | 45.34 | 53.16 | 22.36 | 24.70 | 28.55 | 35,66 | 50.03 | 50.33 | 67.79 | 72.42 | 74.71 | 28.04 | 34.24 | 40.48 | 54.74 | 77.00 | 89.27 | 104.13 | 115.65 | 33.38 | 43.77 | 43.50 53.56 | 65.42 | 73.22 | 88.57 | 107.29 | 125,49 | 160.33 |
| | Inside | area, sq.in. | 12.730 | 11.497 | 0.315 | 7.803 | 20,006 | 18.194 | 16,353 | 14,610 | 12.966 | 29.90 | 73.77 | 21.13 | 18.83 | 51.8 | 51.2 | 50.0 | 47.9 | 40.7 | 40.6 | 38.5 | 37.1 | 36.5 | 82.5 | 80.7 | 78.9 | 14.1 | 68.1 | 64.5 | 60.1 | 26.7 | 118.0 | 114.8 | 111.0 | 108.4 | 106.2 | 101.6 | 96.1 | 90.8 | 80.5 |
| | | ID:In: | 4.026 | 3.826 | 3.624 | 3.152 | 5.047 | 4.813 | 4.563 | 4.313 | 4.063 | 6.065 | 5.75 | 5 187 | 4.897 | 8.125 | 8.071 | 7.981 | 7.813 | 7,020 | 7.457 | 7.007 | 6.875 | 6.813 | 10.250 | 10.136 | 10.020 | 9.750 | 9.312 | 9.062 | 8.750 | 8.500 | 12.250 | 12.090 | 11 938 | 11.750 | 11.626 | 11.374 | 11.062 | 10,750 | 10.126 |
| 1 | Wall | mickness, in. | 0.237 | 0.337 | 0.438 | 0.674 | 0.258 | 0.375 | 0.500 | 0.625 | 0.750 | 0.280 | 0.432 | 0.202 | 0.864 | 0.250 | 0.277 | 0.322 | 0.406 | 0.500 | 0.034 | 0.812 | 0.875 | 0.906 | 0.250 | 0.307 | 0.365 | 0.500 | 0.719 | 0.844 | 1.000 | 1,125 | 0.250 | 0.330 | 0.37.3 | 0.500 | 0.562 | 0.688 | 0.844 | 1.000 | 1312 |
| HODE | Standard, | XX-strong, | STD | ×S | | SXX | STD | XS | | | XXX | STD | ×SX | 100.00000000000000000000000000000000000 | XXX | | * | STD | | SX. | | | XXX | | | | STD | X | | : | xxx | | | : 6 | 9.0 | XS | : | ***** | | SXX | |
| Identification | | Schedule No. | 40 | 80 | 120 | 200 | 40 | 80 | 120 | 160 | | 0 6 | 3 5 | 027 | 8 | 20 | 30 | 40 | 09 | 2000 | 120 | 140 | | 160 | 20 | 30 | 40 | 09 | 8 2 | 120 | 140 | 160 | 20 | 30 | 40 |) | 09 | 80 | 100 | 120 | 160 |
| Size, | nominal | and outside dia, in. | 4 | (4.500) | | | 2 | (5.563) | | | | 9 | (6.625) | | | 00 | (8.625) | | | | | | | No. | 10 | (10.750) | SCHOOL MAN | | | | | | 12 | (12,750) | | | | | | | |
| The same of the sa | External | sq.ft/ft | 0.106 | | 0.141 | 1 | 0.177 | 0000 | 0.220 | | | 0.275 | S. S | | | 0.344 | | | 0.434 | | | | 0,497 | | | A | 0.622 | | | 0.753 | 450, 20 BC000 | | | 0.916 | | | 1.047 | 100000000000000000000000000000000000000 | _ | | |
| | Wt. of | water, lb/ft. | 0.025 | 0.016 | 0.045 | 0.031 | 0.063 | 2000 | 0.132 | 0.00 | 0.022 | 0.230 | 0.187 | 0.127 | 0.063 | 0.374 | 0.311 | 0.220 | 0.647 | 0.555 | 0.457 | 0.273 | 0.882 | 0.765 | 0.610 | 0.412 | 1.45 | 1.28 | 0.77 | 2.07 | 1.83 | 40. | 1.07 | 3.20 | 234 | 1.80 | 4.28 | 3.85 | | | |
| | | Wt/ft, | 0.244 | 0,314 | 0.424 | 0.535 | 0.567 | 0 0 | 1,007 | 1 311 | 1,714 | 1.130 | 1.473 | 1.944 | 2.440 | 1,678 | 2.171 | 3.659 | 2 272 | 2 998 | 3.764 | 5.214 | 2.717 | 3.631 | 4.858 | 6.408 | 3.65 | 20.02 | 9.03 | 5.79 | 7.66 | 10,01 | 13.70 | 7.58 | 14.31 | 18.58 | 9,11 | 12.51 | CHICK | | |
| | Inside | area, sq.in. | 0.0568 | 0.0364 | 0.1041 | 0.0716 | 0.1910 | 00000 | 0.3040 | 0.5340 | 0.0499 | 0.5330 | 0.4330 | 0.2942 | 0.1479 | 0.8640 | 0.7190 | 0.5217 | 1 495 | 1 283 | 1.057 | 0.630 | 2.036 | 1.767 | 1.406 | 0.950 | 3,355 | 2,953 | 1.774 | 4.788 | 4.238 | 3.547 | 2.464 | 7,393 | 5 407 | 4.155 | 9.886 | 8.888 | | | |
| | | ID.in. | 0.269 | 0.215 | 0.364 | 0.305 | 0.493 | 0 0 | 0.646 | 0.0464 | 0.252 | 0.824 | 0.742 | 0.612 | 0.434 | 1.049 | 0.957 | 0.615 | 1 380 | 1 278 | 1.160 | 968'0 | 1.610 | 1.500 | 1.338 | 1.100 | 2.067 | 1.939 | 1.503 | 2.469 | 2.323 | 2.125 | 1,771 | 3.068 | 2 624 | 2,300 | 3.548 | 3.364 | | | |
| - Contraction | Wall | thickness, in. | 0.068 | 0.095 | 0.088 | 0.119 | 0,091 | 0.150 | 0.103 | 0.147 | 0.294 | 0.113 | 0.154 | 0.219 | 0.308 | 0.133 | 0.179 | 0.250 | 0.000 | 191 | 0.250 | 0.382 | 0.145 | 0.200 | 0.281 | 0.400 | 0.154 | 0.218 | 0.436 | 0.203 | 0.276 | 0.375 | 0,552 | 0.216 | 0.300 | 0.600 | 0.226 | 0.318 | 2.20 | | |
| cation | Standard, | XX-strong, | STD | XS | STD | XS | STD | 2 6 | STD | 2 | XXS | STD | xs | | XXS | STD | XS | XXX | CTD | × | : | XXX | STD | XS | | XXS | STD | X | XXX | STD | XS | | SXX | STD | CY. | XXS | STD | XS | | | |
| Identification | | Schedule No. | 40 | 80 | 40 | 80 | 0 6 | 8 5 | 9 8 | 160 | 3 | 40 | 80 | 160 | | 40 | 80 | 160 | 40 | 8 9 | 160 | | 40 | 80 | 160 | | 40 | 08. | 001 | 40 | 80 | 160 | 00000 | 40 | 160 | 2 | 40 | 80 | 200 | | |
| Size | nominal | nd outside dia. in. | 3% | (0.405) | 7,4 | (0.540) | 9/8 | (0.07.0) | % | (0.840) | | × | (1.050) | | | - | (1.315) | | 11% | (1 660) | 500000 | | 1% | (1,900) | 8 | 63869 | 2 | (2.375) | | 21% | (2.875) | 8 | 10.000 | 23 | (3.500) | | 3% | (4.000) | inna. | | |

where p = internal pressure, psig s = allowable fiber stress, psi

From ANSI Standard, Wrought Steel and Wrought Iron Pipe, 838.10–1959, and data of Crane Co. NOTE: Two systems of rating pipe wall thickness are utilized. The newer schedule numbers correspond to definite pressures-stress ratios and are expressed simply as follows:

Properties of the traditional designation for pipe entitled "standard," "extra strong," and "double extra strong" are also shown in the tables.

Schedule No. = 1,000 X P

Pressure Loss Due to Pipe Friction for Standard Steel Pipe

The pressure loss curves on Pages 34 to 46 inclusive are useful to determine the friction losses for various fluids flowing through Schedule 40 new steel pipe. Fluid viscosities are given in Seconds Saybolt Universal (SSU) and centistokes (CS). The horizontal scale at the bottom of each curve shows the rate of flow in gallons per minute and, at the top, the corresponding average velocity in the pipe in feet per second. The vertical scales of friction loss modulus are converted to pressure loss in pounds per square inch or to head loss in feet of liquid as described on the curves.

For example, look at the curve on Page 34. To find the pressure loss for 1/2" pipe for 5 GPM and a liquid with 200 SSU viscosity, enter the curve at the bottom at 5 GPM and note the intersection of the 5 GPM vertical line with the 200 SSU diagonal reference line. A modulus reading of 40 per 100 feet of pipe length can be found at the left margin. The modulus reading is converted to PSI or feet of liquid loss as

described on the curve margin. At the top of the chart directly above 5 GPM, a reading of 5.3 feet per second can be found, which is the velocity for 5 GPM flow in a 1/2" pipe. All of the other curves for other pipe sizes are in the same form and may be read in the same manner. In arriving at the pressure loss of any piping system, an addition must be made for the loss in fittings and valves. The factors in the table below will give an approximate value which can be used as an allowance for the fittings and valves as indicated. Entrance losses from sump to suction pipe are generally less than one foot of head at velocities below 10 ft/sec. Consult a more detailed handbook for losses due to sudden enlargements or contractions.

As no pipe friction loss data can be considered exact for other than the particular conditions from which it was compiled, any pipe friction data, including that furnished herewith, must be used only as a reasonably accurate approximation.

Friction Loss in Standard Valves and Fittings


Table Gives Equivalent Lengths of Straight Pipe in Feet (Laminar Flow)

| | | | | | No | minal | Pipe D | Diamet | ter | | | | |
|-----|--|--|--|--|---|---|--|--|---|--|---|---|---|
| 1/2 | 3/4 | 1 | 11/4 | 11/2 | 2 | 21/2 | 3 | 4 | 5 | 6 | 8 | 10 | 12 |
| .35 | .50 | .60 | .80 | 1.0 | 1.2 | 1.4 | 1.7 | 2.3 | 2.8 | 3.5 | 4.5 | 5.7 | 6.4 |
| 17 | 22 | 27 | 38 | 44 | 53 | 68 | 80 | 120 | 140 | 170 | 220 | 280 | 336 |
| 8 | 12 | 14 | 18 | 22 | 28 | 33 | 42 | 53 | 70 | 84 | 120 | 140 | 168 |
| 1.5 | 2.2 | 2.7 | 3.6 | 4.5 | 5.2 | 6.5 | 8.0 | 11.0 | 14 | 16 | 21 | 26 | 30 |
| 1.3 | 1.8 | 2.3 | 3.0 | 3.6 | 4.6 | 5.5 | 7.0 | 9.0 | 12.0 | 14.0 | 18.0 | 22.0 | 26.0 |
| 1.0 | 1.3 | 1.7 | 2,3 | 2.8 | 3.5 | 4.3 | 5.2 | 7.0 | 9.0 | 11.0 | 14.0 | 17.0 | 20.2 |
| 1.0 | 1.3 | 1.7 | 2.3 | 2.8 | 3.5 | 4.3 | 5.2 | 7.0 | 9.0 | 11.0 | 14.0 | 17.0 | 20.2 |
| 3.2 | 4.5 | 5.7 | 7.5 | 9.0 | 12.0 | 14.0 | 16.0 | 22.0 | 27.0 | 33.0 | 43.0 | 53.0 | 61.0 |
| 3.5 | 5.0 | 6.0 | 8.5 | 10.0 | 13.0 | 15.0 | 18.0 | 24.0 | 30.0 | 37.0 | 50.0 | 63.0 | 74.0 |
| .78 | .97 | 1.23 | 1.6 | 1.9 | 2.4 | 2.9 | 3.6 | 4.7 | 5.9 | 7.1 | 9.4 | 11.8 | 14.1 |
| | .35 17 8 1.5 1.3 1.0 1.0 3.2 3.5 | .35 .50 17 22 8 12 1.5 2.2 1.3 1.8 1.0 1.3 1.0 1.3 3.2 4.5 3.5 5.0 | .35 .50 .60 17 22 27 8 12 14 1.5 2.2 2.7 1.3 1.8 2.3 1.0 1.3 1.7 1.0 1.3 1.7 3.2 4.5 5.7 3.5 5.0 6.0 | .35 .50 .60 .80 17 22 27 38 8 12 14 18 1.5 2.2 2.7 3.6 1.3 1.8 2.3 3.0 1.0 1.3 1.7 2.3 1.0 1.3 1.7 2.3 3.2 4.5 5.7 7.5 3.5 5.0 6.0 8.5 | .35 .50 .60 .80 1.0 17 22 27 38 44 8 12 14 18 22 1.5 2.2 2.7 3.6 4.5 1.3 1.8 2.3 3.0 3.6 1.0 1.3 1.7 2.3 2.8 1.0 1.3 1.7 2.3 2.8 3.2 4.5 5.7 7.5 9.0 3.5 5.0 6.0 8.5 10.0 | ½ ¾ 1 1¼ 1½ 2 .35 .50 .60 .80 1.0 1.2 17 22 27 38 44 53 8 12 14 18 22 28 1.5 2.2 2.7 3.6 4.5 5.2 1.3 1.8 2.3 3.0 3.6 4.6 1.0 1.3 1.7 2.3 2.8 3.5 1.0 1.3 1.7 2.3 2.8 3.5 3.2 4.5 5.7 7.5 9.0 12.0 3.5 5.0 6.0 8.5 10.0 13.0 | ½ ¾ 1 1¼ 1½ 2 2½ .35 .50 .60 .80 1.0 1.2 1.4 17 22 27 38 44 53 68 8 12 14 18 22 28 33 1.5 2.2 2.7 3.6 4.5 5.2 6.5 1.3 1.8 2.3 3.0 3.6 4.6 5.5 1.0 1.3 1.7 2.3 2.8 3.5 4.3 1.0 1.3 1.7 2.3 2.8 3.5 4.3 3.2 4.5 5.7 7.5 9.0 12.0 14.0 3.5 5.0 6.0 8.5 10.0 13.0 15.0 | ½ ¾ 1 1¼ 1½ 2 2½ 3 .35 .50 .60 .80 1.0 1.2 1.4 1.7 17 22 27 38 44 53 68 80 8 12 14 18 22 28 33 42 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 3.2 4.5 5.7 7.5 9.0 12.0 14.0 16.0 3.5 5.0 6.0 8.5 10.0 13.0 15.0 18.0 | ½ ¾ 1 1¼ 1½ 2 2½ 3 4 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 17 22 27 38 44 53 68 80 120 8 12 14 18 22 28 33 42 53 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 3.2 4.5 5.7 7.5 9.0 12.0 14.0 16.0 22.0 3.5 5.0 6.0 8.5 10.0 13.0 15.0 18.0 24.0 <td>.35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 17 22 27 38 44 53 68 80 120 140 8 12 14 18 22 28 33 42 53 70 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 3.2 4.5 5.7 7.5 9.0 12.0 14.0 16.0 22.0 27.0 3.5 5.0 6.0 8.5 10.0 13.0 15.0 18.0 24.0 30.0</td> <td>½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 17 22 27 38 44 53 68 80 120 140 170 8 12 14 18 22 28 33 42 53 70 84 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 1.0 1.3 1.7</td> <td>½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 8 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 4.5 17 22 27 38 44 53 68 80 120 140 170 220 8 12 14 18 22 28 33 42 53 70 84 120 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 21 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 18.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 14.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2</td> <td>½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 8 10 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 4.5 5.7 17 22 27 38 44 53 68 80 120 140 170 220 280 8 12 14 18 22 28 33 42 53 70 84 120 140 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 21 26 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 18.0 22.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 14.0 17.0 1.0</td> | .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 17 22 27 38 44 53 68 80 120 140 8 12 14 18 22 28 33 42 53 70 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 3.2 4.5 5.7 7.5 9.0 12.0 14.0 16.0 22.0 27.0 3.5 5.0 6.0 8.5 10.0 13.0 15.0 18.0 24.0 30.0 | ½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 17 22 27 38 44 53 68 80 120 140 170 8 12 14 18 22 28 33 42 53 70 84 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 1.0 1.3 1.7 | ½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 8 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 4.5 17 22 27 38 44 53 68 80 120 140 170 220 8 12 14 18 22 28 33 42 53 70 84 120 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 21 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 18.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 14.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 | ½ ¾ 1 1¼ 1½ 2 2½ 3 4 5 6 8 10 .35 .50 .60 .80 1.0 1.2 1.4 1.7 2.3 2.8 3.5 4.5 5.7 17 22 27 38 44 53 68 80 120 140 170 220 280 8 12 14 18 22 28 33 42 53 70 84 120 140 1.5 2.2 2.7 3.6 4.5 5.2 6.5 8.0 11.0 14 16 21 26 1.3 1.8 2.3 3.0 3.6 4.6 5.5 7.0 9.0 12.0 14.0 18.0 22.0 1.0 1.3 1.7 2.3 2.8 3.5 4.3 5.2 7.0 9.0 11.0 14.0 17.0 1.0 |

Friction Loss Modulus for 100 Feet of Pipe

Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity


Loss—Feet of Liquid = Modulus x 2.31



Friction Loss Modulus for 100 Feet of Pipe

Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity

Loss—Feet of Liquid = Modulus x 2.31




Pipe Velocity Ft. Per Sec.

Pipe Velocity Ft. Per Sec.


Friction Loss Modulus for 100 Feet of Pipe

Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity

Loss—Feet of Liquid = Modulus x 2.31




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity



Pipe Velocity Ft. Per Sec.

Loss-Lbs. Per Sq. In. = Modulus x Specific Gravity


Friction Loss Modulus for 100 Feet of Pipe



Pipe Velocity Ft. Per Sec.


Friction Loss Modulus for 100 Feet of Pipe

Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity


Loss—Feet of Liquid = Modulus x 2.31



Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity

Loss—Feet of Liquid = Modulus x 2.31




Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity





Loss-Lbs. Per Sq. In. - Modulus x Specific Gravity

Loss—Feet of Liquid — Modulus x 2.31



IMO® Positive Displacement Rotary Pumps

IMO Pump Division, Imo Industries Inc., is the world's largest designer and manufacturer of high performance, positive displacement rotary screw pumps. It produces three positive displacement designs - GTS ™ geared twin screw; CIG™, crescent internal gear; and IMO™, three-screw rotary pumps. Backed with more than 50 years of high performance pumping experience, this precision engineered product line includes pump models to handle flows from one to 8500 gpm, at pressures from 25 to 5000 psi and fluid viscosities from 0.3 to more than a million SSU.

IMO pumps have achieved international recognition for their design simplicity, wide fluid viscosity capabilities, pulsation-free operation, and unusually high reliability over extended periods. Today, IMO has more than one-half million pumps in operation throughout the world. Applications are in a broad range of industries for non-corrosive chemical processing, fuel oil/fluid transfer, lube oil service, hydraulic power, hydraulic sealing and turbine governor use.

GTS™Geared Twin Screw Pumps

GTS geared twin screw pumps find wide application in petroleum production and refining, power generation, petro-chemical, chemical, and many other process industries. They are used in applications wherever large volumes (up to 8500 gpm) of fuels, feeds, intermediates and end products have to be pumped at pressures up to about 500 psi. These pumps can handle liquids with an extremely wide range of viscosities, vapor pressures and densities at temperatures up to and in excess of 600°F (315°C). Because the profile of the pumping screws results in minimum fluid shear, GTS pumps can also be used with paints, greases and other materials exhibiting non-Newtonian rheological behavior.

Typical Applications

Loading, Off-Loading, Cargo Handling and Transfer of:

- Crude oil, light, middle and heavy distillates
- Residual oils, asphalts and tars
- Aromatic, naphthenic and aliphatic intermediates and products
- Fats, oils, waxes and soaps
- Molasses, glycerol, glues, paints, resins and polymers


Design and Operation

The GTS is a geared twin screw positive displacement rotary pump. Externally lubricated timing gears and bearings combined with no internal metal-to-metal contact enable the pumping of non-lubricating fluids as well as aggressive media. This arrangement also allows dry running for unloading and stripping tanks, or for evacuating long suction lines.

The basic pump design is double ended (see diagram at right.) The fluid entering the inlet port (A) is split into two equal portions (B) at the inlet end of each

set of screws. As the rotating screws intermesh, transfer chambers are formed trapping and conveying the fluid axially to the discharge chamber (C) in the center of the pump. It is also possible to reverse direction of flow by reversing the direction of rotation.

GTS pump flow capacity is determined by the lead angle of the screw set. For a given case size, interchangeable screw sets with varying lead angles are available. This enables the flow capability of any one pump to be extended to cover a wide range of requirements.



Features

- Dry Running Capability. External bearings and timing gears plus no internal metal-to-metal contact allow the pumping of non-lubricating fluids as well as dry running.
- Contamination Tolerant. Two-screw, contactfree rotor design handles pumpage with a higher percent of contaminants and/or abrasives without the need for costly filtration systems.
- Wide Viscosity Range. Two-screw, positive displacement design provides uniform, predictable performance regardless of fluid viscosity or temperature.
- Variable Capacity. Shell design permits use of interchangeable screw sets with varying lead angles to provide a wide range of flow, pressure and life capabilities for each case size.
- Self-Priming. With low inlet pressure requirements (NPSH) and inlet port located above the screws, GTS pumps are self-priming under marginal or interrupted flow conditions. They cannot become vapor-locked and are capable of evacuating long, empty suction lines.

- No Cooling Required. High efficiency timing gears plus an oversized lube oil reservoir eliminate the need for costly external cooling systems.
- High Speed Operation. May be direct coupled to more efficient, less costly drivers without the use of gear reduction systems.
- Low Maintenance. Opposed-flow design minimizes axial thrust and thrust bearing wear. Timing gears are ground and hardened for extended life. Replaceable rotor housings allow field repair to reduce downtime and expense.


Options

- Built-in Heating Chamber. Keeps pump at optimum temperature for start-up when pumping viscous fluids.
- Integral Relief Valve. Protects pump from inadvertent overpressure, automatically relieves inlet flow when working pressure is exceeded.
- High Temperature and High Pressure Models. Special purpose units are available for operation at temperatures up to 650° and pressures to 650 psi.

GTS Performance Characteristics

| GTS™ Model No. | | APPL | ICATION | | | SPECIFICATIONS | | | | | | | | |
|----------------------|----------------------|---------------------|---------------------|----------------------|----------------|----------------|-------------|-------------------------------|-------|------------------|------------------|------|-------|--|
| | Process/ Transfer | Fuel Oil Service | Lube Oil Service | Hydraulic Sealing | Fluid Power | Flow Range | | Maximum Discharge Pressure | | Maximum Speed | Maximum Power | | No. | |
| | | | | | | US GPM | LIMIN | PSIG | BAR-G | RPM | HP | KW | Sizes | |
| GTS-074 | | | | | | 5-100 | 55-375 | 300 | 20 | 3600 | 50 | 37 | 5 | |
| GTS-133 | • | 0.82 | | | | 50-750 | 190-2800 | 450 | 31 | 2400 | 150 | 110 | 6 | |
| GTS-208 | | 7,€3 | | | | 450-2700 | 1700-10,200 | 450 | 31 | 1800 | 600 | 450 | 6 | |
| GTS-268 | *: | 0.00 | | | | 1100-4800 | 4100-18,000 | 300 | 20 | 1800 | 800 | 600 | - 6 | |
| GTS-320 | 20 | 7/18/2 | | | | 1400-5400 | 5300-20,500 | 300 | 20 | 1500 | 1000 | 745 | 5 | |
| GTS-400 | *: | 0.00 | | | | 2500-8500 | 9500-32,000 | 300 | 20 | 1500 | 2000 | 1500 | 5 | |

Note: All capabilities are not available in all pumps. Consult your local IMO office or representative for detailed information (see back cover). Special and custom designs are invited.



CIG® Crescent Internal Gear Pumps

Designed for quiet, long lasting, low lubricity operation, the CIG has an operational life of over 30,000 hours - 10 times longer than piston, vane or standard gear pumps. Its noise level is typically 68 db (A) compared to these conventional designs which usually operate at 90 db (A). With ultra-low pressure ripple (0.62% @ 4500 psi), the CIG produces a smooth, constant flow for precision applications. Compact, modular construction permits multi-staging and multi-pump applications to increase pressures or flows in single circuits or to power multiple circuits.

CIG pumps are available in over 1400 performance combinations with speed ranges up to 5700 rpm and can handle a wide range of high performance applications at pressures to 5000 psi and flow rates up to 210 gpm. Fluid viscosity capabilities range from 0.3 cst to over 2157 cst.

Typical Applications

Constant Flow, Fluid Power and Fuel Oil Service Requirements for:


- Manufacturing machinery machine tools, die casting, injection molding and extrusion machinery
- Turbine generators
- Jet engine test stands
- Processing systems packaging, material handling, pulp and paper machinery
- High technology applications computer and medical equipment
- Mobile equipment mining and aircraft ground support equipment

Design and Operation The CIG pump is a posit


The CIG pump is a positive displacement internal gear design. It uses a common shaft driving a pair of patented star-shaped gears for each stage. Hydraulic forces are absorbed on hydrodynamic oil films for long life. Gear tooth profile is such that "trapped volume" is nearly zero at the discharge zone, resulting in exceptionally quiet, ultra-low pulsation operation. The modular design allows stacking of gear sets to achieve high pressures without overstressing parts. It also allows the double pump arrangement - a pump with one inlet port, two independent outlet flows and one input shaft.

CIG pumps based on Truninger QT⁶ system design

This is an important design advantage for applications normally requiring two separate pumps. Double CIG pumps can be used to increase flow in a single circuit or to power two circuits. In such applications, installation space and expense can be reduced due to fewer inlet-side piping requirements and the need for only one driver.



Extra Large Suction and Pressure Zones minimize fluid velocities to reduce noise levels and improve suction capabilities.



Patented Gear Tooth Profile, with essentially straight flanks, virtually eliminates "trapped oil" volume to provide ripple-free flow and low-noise operation.

Features

- Multi-Stage Capability. Modular design permits "stacking" of stages to increase pressure and flow ratings. Over 1400 performance combinations are available.
- Quiet Operation. Extra large suction and discharge areas minimize fluid velocities to maintain low airborn noise levels.
- Constant Flow. Excellent suction capabilities and self-priming characteristics allow fluids to fill the pump smoothly, reducing the possibility of cavitation.
- Ultra-Low Pressure Ripple. Patented gear tooth profile eliminates "trapped oil" volume and corresponding pressure pulsations to further enhance low noise operation.
- Simple, Reliable Design. Each stage consists of only two hydrodynamically supported moving parts which have a typical operating life of over 30,000 hours.
- High Operating Efficiency. Precision designed and manufactured, typical pump volumetric efficiencies are in the 90% range to reduce driver size and cooling requirements as well as overall operating costs.

Wide Fluid Viscosity Range. Handle jet fuels, water glycols, phosphate ester, solvents, fuel oils, hydraulic oils and synthetic fluids with viscosities ranging from .3 cst to over 10,000 SSU.


Options

- Double Pump Combinations. Two CIG pumps assembled on a common shaft with one suction port can increase flows in single circuits or increase power in two separate circuits.
- Mechanical Shaft Seals. Increase reliability for pumping kerosene, diesel fuel, JP-4, Jet-A, #2 fuel oil, Stoddard Solvent and methanol.
- High Temperature Models. Designed for use with fuels at temperatures up to 325° F and hydraulic oils at up to 350° F.
- Ultra-Low Viscosity Models. Allow pumping of low viscosity industrial turbine fuel from .3 cst to over 2157 cst.

CIG Performance Characteristics

| CIG® Model No. | HIME | APPI | JCATION | 1221111111 | | SPECIFICATIONS | | | | | | | | |
|----------------------|---------------------------------------|----------|----------|------------|--------|----------------|--------|-------------------------------|-----|------------------|------------------|-------|-----------|--|
| | Process/ Fuel Oil Transfer Service | Fuel Oil | Lube Oil | Hydraulic | Fluid | Flow Range | | Maximum Discharge Pressure | | Maximum Speed | Maximum Power | | No. of | |
| | | Service | Sealing | Power | US GPM | L/MIN | PSIG | BAR-G | RPM | HP | KW | Sizes | | |
| CIG-2 | | | - | | • | 1-7 | 4-26 | 5000 | 333 | 5700 | 52 | 1.00 | 6 | |
| CIG-3 | | | | | | 2-30 | 8-114 | 5000 | 333 | 4500 | 82 | - | 6 | |
| CIG-4 | | 8.00 | | | - 55 | 3-48 | 11-182 | 5000 | 333 | 3600 | 130 | 1 | 6 | |
| CIG-5 | | 0.00 | | | | 6-75 | 23-284 | 5000 | 333 | 2900 | 207 | - | 6 | |
| CIG-6 | | | | | | 10-118 | 38-447 | 5000 | 333 | 2300 | 329 | - | 6 | |
| CIG-8 | | | | | | 17-122 | 64-462 | 5000 | 333 | 1800 | 500 | | 6 | |

Note: All capabilities are not available in all pumps. Consult your local IMO office or representative for detailed information (see back cover). Special and custom designs are invited.



Typical Flowpath of a Two-Stage CIG.

IMO® Three-Screw Rotary Pumps

The unique IMO three-screw rotary design features only three moving parts and no wearing contact. This simplicity assures high reliability, maximum pumping efficiency and extended pump life with only minimal maintenance. The IMO pump produces non-pulsating flows against varying pressures over a very wide range of fluid viscosities. Operation is extremely quiet and is at standard motor speeds without the use of speed reduction gears.

A wide range of models are available with flow capacities from 1 to 3500 gpm, discharge pressures to 5000 psi and maximum operating speeds to 8000 rpm. When combined with I-MAG™ magnetic drive couplings, the inherent advantages of the IMO three-screw design permit leak-proof, low-maintenance process pumping of non-corrosive fluids.

Typical Applications

High Performance Pumping in Industrial, Petrochemical, Chemical, Oil Production/Refining, Marine and Electric Power Generation Applications for:

- Non-corrosive chemical processing
- Fuel oil/fluid transfer
- Lube oil service
- Hydraulic power
- Hydraulic sealing
- Turbine governor use
- High pressure coolant service




Design and Operation

The IMO rotary screw pump is the original threescrew pump. It is an axial flow, multi-rotor positive displacement design. There are only three moving parts: the power rotor (main screw) and two symmetrically opposed idler rotors. The three rotors are all precision ground screws, with a double lead design, meshing within a close fitting housing to efficiently and quietly deliver continuous, non-pulsating flows. The idler rotors, turned hydraulically by the fluid being pumped, act as rotating seals confining the pumpage in a succession of closures or stages. There is only a rolling action between the power rotor and the idler rotors. This eliminates noise and vibration. Wearing contact is non-existent because the power rotors are free to "float" in their respective bores on a hydrodynamic film created by the pumped fluid.

The IMO pump is balanced both axially and radially. Radial loads are eliminated because the double lead power rotor produces a symmetrical pressure keeping it centered in the bore. Axial loads, created by discharge pressures, are balanced by means of a balance piston at the pump discharge. An external bearing positions the power rotor and is protected from contaminated or low lubricity fluids.

These features allow the IMO pump to assure dependable performance and long life with minimal downtime and maintenance.



Features

- Quiet Operation. Typical airborne noise levels are below 75 db (A) SPL at 3 feet and are well within OSHA requirements.
- Hardened and Precision Ground Rotors. Resist wear due to abrasion and distortion to provide extended pump life. The need for matched rotor sets is eliminated.
- Hydraulically Balanced. Hydraulically induced axial and radial bearing loads are reduced or completely eliminated for low maintenance operations over long service periods.
- Replaceable Rotor Housings. Allow complete field overhaul to the "as new" condition without re-machining or the use of special tools.
- High Speed Capability. Low axial flow velocity and the absence of wearing contact permits direct coupling to high speed drivers. This reduces initial cost and improves operating efficiency.
- External Bearings. Antifriction bearing is externally located and protected from the pumped fluid. It cannot be damaged by contaminants or low lubricity.

Options*

- Integral Relief Valves. Automatically relieve inlet flow when working pressure is exceeded.
- Component Metallurgy. Choice of alloys for casings, rotor housings and rotors to meet specific operating conditions.
- Pump/Drive Packages. Turnkey packages complete with specified drivers. Includes choice of variable speed and variable frequency motors.
- Mounting Configurations. Face or foot mounting in either horizontal or vertical positions without sacrifice in pump performance.
- I-MAG® Magnetic Drive Couplings. Permit leakproof pumping of non-corrosive fluids.

*All options are not available in all pumps. Consult your local IMO office or representative for detailed information (see back cover). Special and custom designs are invited.

| IMO ³ Model No. | | p | PPLICATIO | ON | | SPECIAL | FEATURES | SPECIFICATIONS | | | | | | | |
|----------------------------------|----------------------|---------------------|---------------------|----------------------|----------------|-----------------------------|--|----------------|-------------|-------------------------------|-------|------------------|------------------|-----|-------------|
| | Process/ Transfer | Fuel Oil Service | | Undersitte | Thola | Integral Relief Valve | I-MAG® Magnetic Drive Coupling* | Flow Range | | Maximum Discharge Pressure | | Maximum Speed | Maximum Power | | No. |
| | | | Lube Oil Service | Hydraulic Sealing | Fluid Power | | | US GPM | L/MIN | PSIG | BAR-G | RPM | HP | KW | of Sizes |
| 3E | | • | | | | | | 1-100 | 4-375 | 150 | 10 | 8000 | 20 | 15 | 10 |
| 3R | * | | *: | | | | | 150-1100 | 570-4100 | 300 | 20 | 1800 | 320 | 240 | 10 |
| 110H | ×: | | | | 200 | | | 2-7 | 7-25 | 1500 | 100 | 5000 | 10 | 7.5 | 2 |
| 210H | * | | | | | | | 7-16 | 25-60 | 1500 | 500 | 5000 | 30 | 22 | 4 |
| 3D | * | • | * | (*) | | | | 5-400 | 20-1500 | 500 | 35 | 5000 | 150 | 110 | 11 |
| 6D | ×: | | | | | | | 5-400 | 20-1500 | 1500 | 100 | 5000 | 300 | 225 | 12 |
| 12D | ×: | * | | | | | | 5-250 | 20-950 | 2200 | 150 | 5000 | 350 | 260 | 10 |
| ACE | | | * | | | *: | | 4-44 | 16-176 | 150 | 10 | 4000 | 10 | 7.5 | 5 |
| UCG | *: | | * | | | * | | 30-280 | 110-1060 | 250 | 18 | 4000 | 75 | 56 | 4 |
| UCF | * | | | | | | | 120-800 | 480-3200 | 175 | 12 | 2000 | 150 | 110 | 7 |
| 8L | | * | | | | | | 250-900 | 950-3400 | 1500 | 100 | 2300 | 1000 | 745 | -5 |
| 12L | *: | | | 300 | | | | 15-100 | 55-375 | 5000 | 345 | 4400 | 370 | 275 | 5 |
| 4U | | | | | | | | 15-175 | 55-660 | 1500 | 140 | 4400 | 300 | 225 | 7 |
| 6U | | | | | 64.0 | | | 15-175 | 55-660 | 2500 | 170 | 4400 | 450 | 335 | 8 |
| 4T | | | | | | | | 15-175 | 55-660 | 1500 | 100 | 4400 | 225 | 170 | 7 |
| 6T | | | | | | | | 15-175 | 55-660 | 2500 | 170 | 4400 | 375 | 280 | 7 |
| 323F | *: | *: | * | | | | | 400-3500 | 1500-13,250 | 300 | 20 | 1500 | 775 | 575 | 4 |
| 324A | *5 | * | | | | | | 50-900 | 200-3400 | 500 | 35 | 4200 | 350 | 260 | 10 |
| T324 | * | | | | | | | 300-800 | 1125-3000 | 700 | 50 | 2300 | 425 | 315 | 2 |

^{*}Optional

Note: All capabilities are not available in all pumps. Consult your local IMO office or representative for detailed information (see back cover). Special and custom designs are invited.

I-MAG® Magnetic Drive Couplings


Permit leak-proof, low-maintenance pumping of noncorrosive fluids with all of the advantages of the IMO rotary screw pump design.

- Five coupling sizes for use with IMO 3D, 6D and 12D and 324 Series Pumps.
- Handle flow rates from 5 to 900 gpm at pressures to 2200 psi and speeds to 3600 rpm.
- Elimination of dynamic seals minimizes maintenance and replacement costs associated with shaft seals.
- Hydraulically balanced elements eliminate the need for thrust plates or additional bearings.
- Available in either C-face or frame mounted configurations. Optional bearing carrier permits long-coupling.
- Proven low noise design.



Model A3D with 15 hp magnetic drive and TEFC motor, 15 gpm, 300 psig discharge, 9600 SSU, 1200 rpm. Horizontal foot mounted.

IMO® Three-Screw Rotary Pump Quick Selection Chart



The reliable pump people



A Member of the COLFAX PUMP GROUP

Imo Pump

1710 Airport Road

PO Box 5020

Monroe, NC

28111.5020

USA

tel +1 (704) 289 6511

fax +1 (704) 289 9273

E-mail

Imo.Pump@ColfaxCorp.com

Internet

http://www.imo-pump.com











COLFAX PUMP GROUP



Quality Management System